



# **CORRECTION ORDER**

CITY OF DETROIT

Property Maintenance Division

Buildings, Safety Engineering, and Environmental Department

Room 412, Coleman A. Young Municipal Center

Detroit, Michigan 48226

Case Number: ANN2004-11329

Location: 1445 E LAFAYETTE

Inspector: Insp. W. Sparks

Supervisor: Ronald Muir

Legal Occupancy: SCHOOL

Tenant: CHRYSLER ELEMENTARY SCHOOL

Sector: 4 District: 30

Use Group: E

Zoning District:

Telephone: 313-224-BSED (2733)

Telephone inquiries may be made between  
8:00 am and 4:00 pm, Monday through Friday.

March 03, 2016

DETROIT PUBLIC SCHOOLS

3031 W. GRAND BLVD

DETROIT, MI 48202

**The Property Maintenance Branch inspected the above premises on 3/2/2016.**

Violations of the Detroit **Property Maintenance Code and/or Official Zoning Ordinance** were found to exist and corrections shall be made on or before **3/1/2016**.

## **Violations**

- 1 (2015)-Secure the required annual "Certificate of Compliance" from this department. (Sec. 9-1-36a)
- 2 (2015)-For compliance you are required to pay the prescribed inspection fee, in addition to complying any existing violations. (Sec 9-1-35)

**NOTE: YOU ARE REQUIRED TO OBTAIN A CERTIFICATE OF COMPLIANCE FOR YOUR PROPERTY. UNDER CERTAIN CONDITIONS YOU MAY BE ENTITLED TO RECEIVE A TEMPORARY CERTIFICATE OF COMPLIANCE WHILE CORRECTIONS ARE IN PROGRESS.**

**TO RECEIVE THE REQUIRED CERTIFICATE OF COMPLIANCE FOR INSPECTION OR MAINTENANCE OF GRANT CONDITIONS, YOU MUST PERFORM THE FOLLOWING:**

1. **CORRECT ALL OF THE DEFICIENCIES LISTED ABOVE.**
2. **PAY THE REQUIRED INSPECTION FEES AS INVOICED.**
3. **CALL (313) 628-2451 FOR A RE-INSPECTION AFTER CORRECTION OF DEFICIENCIES AND PAYMENTS OF THE FEES AS INVOICED.**

**YOUR FAILURE TO COMPLY WITH THE ABOVE WILL RESULT IN THE ISSUANCE OF ONE OR MORE TICKETS WHICH WILL BE HEARD AT THE CITY OF DETROIT, DEPARTMENT OF ADMINISTRATIVE HEARINGS, WHICH IS LOCATED AT 1004 COLEMAN A. YOUNG MUNICIPAL CENTER, DETROIT, MICHIGAN 48226.**