

**DETROIT HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH & SAFETY
FIELD INVESTIGATION REPORT**

RESIDENT/BUSINESS NAME: CODY HIGH SCHOOL

ADDRESS: 18445 CATHERAL STREET, DETROIT, MI 48227

COMPLAINANT: Referral

TYPE OF INVESTIGATION:

Air Quality	<u> </u>	Hazardous Waste	<u> </u>
Environmental	<u>✓ </u>	Solid Waste	<u> </u>

NATURE OF COMPLAINT: DETROIT PUBLIC SCHOOLS

NATURE OF COMPLAINT: Potential health-related violations observed by BSEED inspectors.

Date of Inspection: 2/10/16

INVESTIGATION SUMMARY: An environmental health inspection was conducted at Cody High School. Representatives from the Detroit Health Department-Environmental Health and Safety assessed the over-all environmental health and safety conditions of this DPS school facility.

Findings and Recommendations:

1. Missing and stained ceiling tiles show evidence of possible roof leaks. Inspect roof to assure it is weather-tight, remove stains and replace missing and broken ceiling tiles. Repair all water damaged ceiling surfaces. Provide a confirmation of roof inspection from a 3rd party certified roofing contractor. If repairs are needed, supply a separate plan of action for roof and expected date of completion within 72 hours.
2. Replace missing tiles throughout the building within 30 days.
3. Repair non-working drinking fountains outside clinic within 30 days.
4. Failure to conduct the proper repairs within a timely manner will result in a recommendation of facility closure and the revocation of Certificate of Occupancy from the Detroit Health Department. Health Department representatives will follow up in 72 hours on roof inspection, and 30 days for all other findings.

CONDUCTED BY: Detroit Health Department Environmental Team **Date:** 2/10/16

ROUTINE	Phone COMPLAINT	REFERRAL ✓
----------------	------------------------	----------------------



CONDUCTED BY: Detroit Health Department Environmental Team Date: 2/10/16

ROUTINE	Phone COMPLAINT	REFERRAL √
---------	-----------------	---------------