



ANALYTICAL RESULTS

Workorder: 207594 UNIV YES- 041816

Lab ID: 2075940001	Date Collected: 4/18/2016 06:00	Matrix: Drinking Water (Potable)
Sample ID: UNIVERSITY YES	Date Received: 4/18/2016 14:00	
Sample Desc: GRAB	PO:	

Parameters	Qualifier	Result Units	Dilution Factor	Reporting Limit	Result Qualifier		Analyzed	By
					Min	Max		
Metals								
Analytical Method: EPA 200.8								
Copper, Total		0.15 mg/L	1	0.0010		1.3	4/21/2016 14:51	VAH
Lead, Total		<0.0010 mg/L	1	0.0010		0.015	4/21/2016 14:51	VAH

Paragon Laboratories, Inc. is certified by the Michigan DEQ to analyze Drinking Water. (MDEQ Lab No. 9901 Expires 2/25/2017)
 This report shall not be reproduced, except in full, without the written consent of Paragon Laboratories, Inc..

Generated: 4/28/2016 11:39:18 AM



PARAGON
Laboratories

CHAIN-OF-CUSTODY

ID

207594
UNIV YES
UNIVERSITY YES

12649 Richfield
P 734.462.3900 F 734.462.39

Page ___ of ___

Client Name: <u>University Yes</u>		INTERNAL USE ONLY									
Contact Person:		Paragon Report No.: <u>207594</u>									
Mailing Address:		Logged By: <u>ADS</u>									
City, State, Zip:		Sample Condition Upon Receipt: <u>Acceptable</u> Other (Specify Below)									
Phone and Fax:		Volatiles Preserved: Yes No Metals FF: Yes No Metals Pres: Yes No									
Email:		Remarks: <u>Samples received on natural gas ADS WTR</u>									
Client Job Name / No.:		ANALYSIS REQUESTED									
Job Location:		PO No.:									
Sampled By:		Matrix Key									
Regulatory Requirements		Turnaround Requirements									
RCRA <input type="checkbox"/> 24 Hour (RUSH) <input type="checkbox"/>		DW = Drinking Water WW = Wastewater									
NPDES <input type="checkbox"/> 2 Day (RUSH) <input type="checkbox"/>		W = Water D = Diesel BD = Biodiesel									
Drinking Water <input type="checkbox"/>		G = Gasoline E8 = E85 O = Oil									
Other: _____		SL = Sludge S = Soil X = Other									
Item No.	Date Taken	Time Taken	Comp	Client Sample ID	Date	Received By	Time	Tran. #	Released By	Date	Time
1	4/18	6:00	X	W1	4/18/16	<i>[Signature]</i>	1400	3.			
2.								4.			