

Mr. Hosam Hassaniien, PG, CPG  
City of Detroit  
Environmental Affairs  
2 Woodward Avenue – CAYMC, Suite 401  
Detroit, MI 48226

January 25, 2024  
NTH Project No. 74-200457-07

**RE: Ambient Air Quality Monitoring – 3<sup>rd</sup> Post-Construction Phase Monitoring Report  
November 3, 2023 – November 12, 2023  
Amazon Distribution Center  
Detroit, Michigan**

Dear Mr. Hassaniien:

The City of Detroit (City) completed a property transaction for a new Amazon Distribution Center constructed on a 137-acre parcel at the former State Fairgrounds property located at 1120 W. State Fair Avenue in Detroit, Michigan. The City contracted NTH Consultants, Ltd. (NTH) to conduct ambient air quality monitoring at the proposed Amazon Distribution Center site (Site).

The monitoring program consists of siting localized monitors at upwind and downwind locations to measure concentrations of particulate matter (PM<sub>10</sub> and PM<sub>2.5</sub>), nitrogen oxide (NO<sub>x</sub>, as NO<sub>2</sub>), and volatile organic compounds (VOCs), and to evaluate air quality from the Site during three (3) distinct phases:

- Pre-development baseline period
- Construction phase
- Post-construction facility operation

**PRE-DEVELOPMENT BASELINE PERIOD (COMPLETED)**

NTH's Baseline Monitoring Report, dated May 7, 2021, presented ambient concentrations prior to significant construction activities at the Site. The baseline period included monitoring data collected by Montrose Air Quality Services, LLC (MAQS), from January 22, 2021 through March 5, 2021, and was supplemented with monitoring data collected by the Site developer's consultant (Langan) from November 13, 2020 through December 2, 2020. The purpose of the Baseline Monitoring Report was to establish an ambient background concentration for each pollutant and use that concentration as a baseline whereas concentrations measured above these levels during construction would trigger the contractor to employ additional mitigation efforts in order to reduce pollutant concentrations.

The concentrations in Table 1 were published in the Baseline Monitoring Report and represent pollutant concentrations prior to the start of significant construction activities. Each concentration is also compared to the applicable National Ambient Air Quality Standards (NAAQS) protective of public health and the environment.

**Table 1 – Site-Specific Baseline Concentrations from Pre-Development Baseline Period**



Pollutant	Operator	Monitor <sup>1</sup>	Baseline Concentration	Date of Baseline Concentration	NAAQS	Units
PM <sub>10</sub>	Langan	ML2	47	11/25/2020	150	µg/m <sup>3</sup>
PM <sub>2.5</sub>	Langan	ML2	22	11/25/2020	35	µg/m <sup>3</sup>
NO <sub>2</sub>	MAQS	Unit 1480	52	1/30/2021	100	ppb
VOC	Langan	ML1	0.11	11/14/2020	NA <sup>2</sup>	ppm

<sup>1</sup> Baseline Monitoring included two (2) Site monitors operated by MAQS for NTH from January 22 through March 5, 2021, and identified as Unit 1479 (“upwind”, located to the southwest of the Site) and Unit 1480 (“downwind”, located to the northeast of the Site), as well as monitoring data provided by Hillwood Development Company (HDC), the project developers, for the period November 13, 2020 through December 2, 2020 from five (5) monitoring locations at the project Site and identified as ML1, ML2, ML3, ML4 and ML5. For the post-construction phase, Unit 1479 was replaced by Unit 1838, and Unit 1480 was replaced by Unit 1839, as discussed in the 1<sup>st</sup> Post-Construction Phase Monitoring Report dated August 10, 2023.

<sup>2</sup> NAAQS have not been established for VOC. VOCs are considered precursors to the formation of ozone. Ozone is formed downwind by photochemical reaction of NO<sub>x</sub> and VOCs in certain ambient conditions (typically hot, sunny weather)

### CONSTRUCTION PHASE MONITORING (COMPLETED)

NTH’s six (6) Construction Phase Monitoring Reports represented ambient concentrations during construction. The reports included monitoring data collected by MAQS and supplemented with monitoring data collected from Michigan Department of Environment, Great Lakes, and Energy (EGLE) monitoring sites. The goal of construction phase monitoring was to collect concentration data of target air pollutants during construction activities consisting of paving, concrete work, steel construction, roofing, interior buildout, electrical work, and plumbing. Construction was completed and the facility was turned over to Amazon in April 2023.

None of the six (6) Construction Phase Monitoring Reports indicated a threat to public health or the environment. PM<sub>10</sub>, PM<sub>2.5</sub>, NO<sub>2</sub>, and VOCs results were analyzed and compared to baseline concentrations and NAAQS. None of the analyzed parameters exceeded NAAQS during any of the Construction Phase Monitoring events. Particulate matter did exceed baseline concentrations during two (2) of the Construction Phase Monitoring events but was determined to be due to wildfires in the western United States and Canada and sustained local elevated wind speeds.

### POST-CONSTRUCTION PHASE MONITORING

The City anticipates that the operation of Amazon Distribution Center may result in direct and fugitive air emissions. Sources of NO<sub>x</sub>, VOC, PM<sub>10</sub> and PM<sub>2.5</sub> emissions related to operation may include vehicular traffic (employee vehicles or delivery trucks) or the associated fugitive dust.

The data collected during the post-construction phase air monitoring events completed to date were not indicative of a threat to public health or unusual concentrations of the analyzed parameters.

The enclosed report presents the results of the 3<sup>rd</sup> post-construction phase monitoring event that was conducted for the period of November 3 through November 12, 2023 using two Site monitors identified as Unit 1838 and Unit 1839, which operated simultaneously for ten (10) days. This report describes the monitoring program, objectives, Site overview, monitor locations and equipment, monitoring results, and an overview of data quality assurance. The goal of post-construction phase monitoring is to collect concentration data of target air pollutants during regular operation of the

facility to assess whether additional mitigation efforts are warranted to reduce pollutant concentrations to below baseline levels.

The monitors were located on opposite sides of the Site and both stations are configured to collect pollutant and meteorological data. An upwind monitor measures pollutant concentrations that have not blown across the Site and should be free from potential impacts of on-site development activity and is representative of local area background concentrations.

The report includes monitoring data from two (2) available sources, including:

- Two (2) Site monitors identified as Unit 1838 (“upwind”, located to the southwest) and Unit 1839 (“downwind”, located to the northeast) and operated by MAQS for NTH during the monitoring period of November 3 through November 12, 2023.
- Nearby off-site monitors operated by Michigan Department of Environment, Great Lakes, and Energy (EGLE) during the MAQS monitoring period.

As part of this air monitoring program, MAQS collected air monitoring data over this period for NO<sub>x</sub> (as NO<sub>2</sub>), PM<sub>10</sub> and PM<sub>2.5</sub>, and VOCs at two (2) monitors, along with wind directions and speeds (vectors).

## RESULTS OF POST-CONSTRUCTION PHASE MONITORING

As presented below and in the enclosed report, for monitoring conducted November 3 through November 12, 2023, concentrations of PM<sub>10</sub>, PM<sub>2.5</sub>, NO<sub>x</sub> (as NO<sub>2</sub>), and VOC from the on-site monitors are less than their baseline concentrations and NAAQS, as summarized in Table 2. Monitored concentrations of PM<sub>10</sub>, PM<sub>2.5</sub> are also less than the 24-hour NAAQS of 150 µg/m<sup>3</sup> for PM<sub>10</sub>, 35 µg/m<sup>3</sup> for PM<sub>2.5</sub><sup>1</sup>.

For this post-construction phase monitoring event, NTH’s objective was to obtain at least seven (7) days of air quality data at the site. Unit 1838 and 1839 both recorded valid PM<sub>10</sub> and PM<sub>2.5</sub> daily averages for ten (10) days.

**Table 2 – Summary of Air Monitoring from November 3 through November 12, 2023**

Pollutant	Maximum Concentration	Monitor	Date of Maximum Concentration	Baseline Concentration	NAAQS	Units
PM <sub>10</sub>	9.3	Unit 1839	11/6/2023	47	150	µg/m <sup>3</sup>
PM <sub>2.5</sub>	7.6	Unit 1839	11/5/2023	22	35	µg/m <sup>3</sup>
NO <sub>2</sub>	33.1	Unit 1839	11/4/23	52	100	ppb
VOC	0.03	Unit 1838 Unit 1839	11/12/2023 11/10/2023	0.11	NA <sup>1</sup>	ppm

<sup>1</sup> NAAQS have not been established for VOC. VOCs are considered precursors to the formation of ozone. Ozone is formed downwind by photochemical reaction of NO<sub>x</sub> and VOCs in certain ambient conditions (typically hot, sunny weather)

In summary, the data collected during this air monitoring event are not indicative of a threat to public



health or unusual concentrations of the analyzed parameters.

We appreciate this opportunity to be of service to you. If you have questions or need additional information, please contact us at 248-662-2740.

Sincerely,

NTH Consultants, Ltd.

DocuSigned by:  
*Christopher O. Occhipinti*  
F72D85E12731430...

Christopher O. Occhipinti  
Senior Project Professional

DocuSigned by:  
*Bhushan C. Modi*  
2B348C09314C474...

Bhushan C. Modi  
Project Manager

COO/BCM/mam

Attachments

**3<sup>rd</sup> POST-CONSTRUCTION PHASE MONITORING  
REPORT  
NOVEMBER 3, 2023 – NOVEMBER 12, 2023  
AMAZON FULFILLMENT CENTER (FORMER  
MICHIGAN STATE FAIRGROUNDS)  
CITY OF DETROIT  
DETROIT, MICHIGAN**

Prepared For:  
**NTH Consultants, Ltd.**  
2990 W. Grand Blvd., Suite M-10  
Detroit, MI 48202

Prepared By:  
**Montrose Air Quality Services, LLC**  
45 U.S. 46, Suite 601  
Pine Brook, NJ 07058

Document Number:           **027AA-020300-RT-86**  
NTH Project Number:       **74-200457-03**  
Monitoring Period:         **November 3, 2023 through November 12, 2023**  
Submittal Date:             **December 1, 2023**



# Table of Contents

<b>PROJECT OVERVIEW .....</b>	<b>1</b>
<i>Background.....</i>	<i>1</i>
<i>Objectives .....</i>	<i>2</i>
<i>Potential Sources.....</i>	<i>2</i>
<i>Site Overview.....</i>	<i>4</i>
<i>Figure 1-A – Monitor Locations at the Proposed Amazon Distribution Center (Former Michigan State Fairgrounds).....</i>	<i>4</i>
<i>Figure 1-B – Monitor Locations at the Proposed Amazon Distribution Center (Former Michigan State Fairgrounds) Property and Nearby MI EGLE Monitoring Stations.....</i>	<i>5</i>
<i>Monitoring Equipment.....</i>	<i>6</i>
<i>Discussion of Results.....</i>	<i>6</i>
<b>METEOROLOGICAL DATA COLLECTED .....</b>	<b>8</b>
<i>FIGURE 2-A – Wind Rose From 1838 Monitor.....</i>	<i>8</i>
<i>FIGURE 2-B – Wind Rose From 1839 Monitor.....</i>	<i>8</i>
<b>POLLUTANT DATA COLLECTED .....</b>	<b>10</b>
<i>Figure 3 – PM<sub>10</sub> Data.....</i>	<i>10</i>
<i>Figure 4 – PM<sub>2.5</sub> Data.....</i>	<i>11</i>
<i>Figure 5 – NO<sub>2</sub> Data.....</i>	<i>12</i>
<i>Figure 6 – VOC Data.....</i>	<i>13</i>
<b>DATA QUALITY ASSURANCE/QUALITY CONTROL .....</b>	<b>14</b>
<i>Quality Assurance/Quality Control.....</i>	<i>14</i>
<b>SIGNATURE PAGE .....</b>	<b>15</b>
<b>APPENDIX .....</b>	<b>16</b>
A: Quality Assurance Logs	
B: Calibration Certification Sheets	
C: State Monitor Map	

## Project Overview

### Background

NTH Consultants, Ltd. (NTH) has retained Montrose Air Quality Services, LLC (Montrose) to conduct an ambient air quality monitoring program in support of an Amazon Fulfillment Center construction project located on a portion of the former Michigan State Fairgrounds in Detroit, Michigan. The monitoring program collects, validates and reports continuously-measured, hourly-averaged data for a mixture of pollutants that may originate from construction activities at the Site, as well as emissions from vehicular traffic, diesel engines, surface attrition, other sources of dust emissions, and future Site operations.

The monitoring program is conducted in accordance with the schedule, monitoring protocols and procedures contained in approved Monitoring Test Plans. The monitoring program consists of several phases, starting with a pre-construction monitoring period conducted to characterize and establish baseline background concentrations at the Site. Following completion of the Pre-construction monitoring, six (6) one-week monitoring periods were conducted during the construction phase of the project. Construction Phase monitoring commenced in April 2021 and concluded in October, 2021.

The monitoring program will conclude by conducting a total of four (4) one-week Post-Construction monitoring periods. Post-Construction monitoring will be conducted at approximately 3-month intervals.

A summary of the monitoring program and associated deliverables completed to date follows:

- A Pre-Construction “Baseline” Report, dated May 7, 2021 presents data collected from two on-site monitors operated by Montrose supplemented with data collected from selected off-site monitors operated by the Michigan Department of Environment, Great Lakes, and Energy (EGLE) for the period commencing January 22, 2021 and concluding March 5, 2021. The pre-construction monitoring report also incorporated monitoring data collected by the land developer for the period November 13, 2020 through December 2, 2020.
- The first Construction Phase Report, dated June 8, 2021 presents monitoring data collected from two on-site monitors operated by Montrose for the period commencing April 14 and concluding April 21, 2021.
- The second Construction Phase Monitoring Report presents data collected from two on-site monitors operated by Montrose supplemented with data collected from selected off-site monitors operated by the EGLE for the monitoring period commencing on June 20 and concluding on June 27, 2021.
- The third Construction Phase Monitoring Report presents data collected from two on-site monitors operated by Montrose supplemented with data collected from selected off-site monitors operated by EGLE for the monitoring period commencing on July 18 and concluding on July 24, 2021.
- The fourth Construction Phase Monitoring Report presents data collected from two on-site monitors operated by Montrose supplemented with data collected from selected off-site monitors operated by EGLE for the monitoring period commencing on August 15 and concluding on August 21, 2021.
- The fifth Construction Phase Monitoring Report presents data collected from two on-site monitors operated by Montrose supplemented with data collected from selected off-site monitors operated by EGLE for the monitoring period commencing on September 19 and concluding on September 28, 2021.
- The sixth Construction Phase Monitoring Report presents data collected from two on-site monitors operated by Montrose supplemented with data collected from selected off-site monitors operated by EGLE for the monitoring period commencing on October 13 and concluding on October 24, 2021.

- The first Post-Construction Phase Monitoring Report presents data collected from two on-site monitors operated by Montrose supplemented with data collected from selected off-site monitors operated by the EGLE for the monitoring period commencing on May 13 and concluding on May 29, 2023.
- The second Post-Construction Phase Monitoring Report presents data collected from two on-site monitors operated by Montrose supplemented with data collected from selected off-site monitors operated by the EGLE for the monitoring period commencing on August 22 and concluding on August 28, 2023.
- This third Post-Construction Phase Monitoring Report presents data collected from two on-site monitors operated by Montrose supplemented with data collected from selected off-site monitors operated by the EGLE for the monitoring period commencing on November 3 and concluding on November 12, 2023.

## **Objectives**

The specific objectives of the Post-Construction monitoring effort are defined in Section 1.1 of the approved Post-Construction Ambient Air Test Plan for the Amazon Fulfillment Center at the Former Michigan State Fairgrounds dated January 31, 2023. These objectives are to measure ambient concentrations of the following parameters at two (2) monitoring locations at the Site:

- Particulate Matter (PM<sub>10</sub>) of diameter equal to or less than 10 microns
- Particulate Matter (PM<sub>2.5</sub>) of diameter equal to or less than 2.5 microns
- Nitrogen Dioxide (NO<sub>2</sub>)
- Volatile Organic Compounds (VOC)
- Meteorological parameters (i.e., wind speed, wind direction, temperature, relative humidity, and barometric pressure)

To accomplish these objectives, two air quality and meteorological monitors were deployed at the Site to concurrently collect continuous measurements for the parameters listed above. The Unit 1838 monitor was situated “upwind”, located to the southwest (latitude 42.440184°, longitude -83.119514°) and Unit 1839 was situated “downwind”, located to the northeast (latitude 42.443536°, longitude -83.111440°), as presented in Figure 1-A. Continuous measurement data collected from each monitor were reduced and reported as hourly block-averaged values.

## **Potential Sources**

Sources of NO<sub>2</sub>, VOC, PM<sub>10</sub> and PM<sub>2.5</sub> emissions related to operation may include vehicular traffic and associated fugitive dust.



## **Operational Staff and Contacts**

### **Facility Information**

Monitoring Location: Amazon Fulfillment Center  
Former Michigan State Fairgrounds  
20110 Woodward Avenue  
Detroit, MI 48203

### **Monitoring Program Coordinator**

NTH Consultants, Ltd.  
3300 Eagle Run Drive NE, Suite 202  
Grand Rapids, MI 49525

Project Contacts: Mr. Chris Occhipinti  
Role: Project Professional  
Company: NTH Consultants, Ltd.  
Telephone: 616-951-4774  
Email: cocchipinti@nthconsultants.com

### **Monitoring Team Contact Information**

Testing Firm: Montrose Air Quality Services, LLC (Montrose)

Contact: David Cummings  
Title: District Manager  
Telephone: 201-213-2913  
Email: dcummings@montrose-env.com

Contact: Kevin Ruggiero  
Title: Sr. Project Manager  
Telephone: 973-417-6487  
Email: kruggiero@montrose-env.com

Contact: Jeffrey Peitzsch  
Title: Shop Coordinator  
Telephone: 313-213-4816  
Email: jbpeitzsch@montrose-env.com

Contact: Linda Quigley  
Title: Senior Reporting QC Specialist  
Telephone: 973-575-2555 (Ext. 12707)  
Email: lquigley@montrose-env.com

**Site Overview**

The Site air quality monitoring was performed at the newly constructed Amazon Fulfillment Center situated on a portion of the former Michigan State Fairgrounds property located at 20110 Woodward Avenue in Detroit, MI. This area was purchased by Hillwood Development Company, LLC (Hillwood) who demolished the existing structures onsite and constructed a large warehouse occupied by the Amazon Fulfillment Center. The locations of the two (2) on-site monitors are identified in Figure 1-A below.

**Figure 1-A – Monitor Locations at the Amazon Fulfillment Center (Former Michigan State Fairgrounds) Property**







Figure 1-B is an aerial view of the two monitoring site locations at the Amazon Fulfillment Center (Former Michigan State Fairgrounds) property and two nearby air monitoring stations maintained by the Michigan Department of Environment, Great Lakes, and Energy (EGLE). Monitoring data available from the two nearby EGLE monitoring stations are intercompared in this report with corresponding monitoring data reported from the two monitors operated by Montrose at the former Michigan State Fairgrounds property.

**Figure 1-B – Monitor Locations at the Amazon Fulfillment Center (Former Michigan State Fairgrounds) Property and Nearby MI EGLE Monitoring Stations**



## Monitoring Equipment

Air monitoring at the Amazon Fulfillment Center (former Michigan State Fairgrounds) was performed using two Aeroqual Model AQS-1 Urban Air Quality Monitors. The AQS-1 monitors continuously sample for pollutant parameters by actively pulling in ambient air via a pump and passing the sample air stream over the surface of each sensor. Each AQS-1 monitor used in this project is powered by deep-cycle batteries charged by solar photovoltaic panels. The measurement data are acquired and processed by an inboard, microprocessor-based computer and values are stored in non-volatile, electronic memory. An inboard integrated wireless data modem transmits the data via cellular service to a secure, cloud-based data platform. Monitoring was conducted for the constituents listed in Table 1.

**Table 1 - Pollutants Monitored**

Air Pollutant/Parameter Category	Principle of Operation
PM <sub>10</sub> and PM <sub>2.5</sub>	Laser Scattering
NO <sub>2</sub>	Electrochemical
VOC	Photoionization
Wind Speed, Wind Direction, Temperature, Relative Humidity, Barometric Pressure	Sonic Anemometer and Various

Measurement of particulate matter (PM<sub>10</sub> and PM<sub>2.5</sub>) is accomplished using the physical principle of light scattering. As the sample air stream is drawn through a detector module, each single particle in the air stream is illuminated by a defined laser light and each scattering signal is detected at an angle of 90° by a photo diode. In accordance with the Mie theory, each measured pulse height is directly proportional to the particle size, where each pulse is classified in an electronic register of 32 different size channels.

A separate electrochemical sensor measures concentrations of NO<sub>2</sub> via oxidation or reduction reactions in an electrochemical sensor. These reactions generate a positive or negative current flow through an electronic detector circuit. The electrochemical sensor is made up of a working counter and reference electrode. All of these components are situated inside of a sensor housing along with a liquid electrolyte that is specific to the compound of interest, i.e., NO<sub>2</sub>.

A Photoionization Detector (PID) sensor is used for detection and measurement of VOC. The PID contains a lamp that produces photons that carry enough energy to break molecules into ions. The PID will only respond to molecules that have an ionization energy at or below the energy of the lamp; the PID used on this project employs a 10.6 electron-volt lamp. The ions produced by the PID generate an electrical current that is measured as the output of the detector.

The continuous monitoring equipment utilized in this project were operated and maintained in accordance with the procedures and quality control elements contained in the Post-Construction Ambient Air Test Plan for the Amazon Fulfillment Center at the Former Michigan State Fairgrounds dated January 31, 2023.

## Discussion of Results

The results of PM<sub>10</sub>, PM<sub>2.5</sub>, NO<sub>2</sub>, and VOC monitoring data are presented in Figures 3 through 6 in this report. These figures also include data for the same time period reported from nearby air monitoring stations maintained by the Michigan Department of Environment, Great Lakes, and Energy (EGLE). The EGLE data contained in this report are from monitors that are routinely subjected to calibration and maintenance. It should be noted that, as of the date of this report, the EGLE data have not yet been processed through

EGLE final quality assurance procedures. The monitor locations for EGLE Sites are depicted in Figure 1-B and can also be found on the map provided in Appendix C (*State Monitor Map*).

The Clean Air Act requires EPA to establish National Ambient Air Quality Standards (NAAQS) for certain air pollutants considered harmful to public health and the environment. Air pollutants for which NAAQS are established include NO<sub>2</sub>, PM<sub>2.5</sub> and PM<sub>10</sub>. NAAQS have not been established for VOCs. VOCs are considered precursors to the formation of ozone. Ozone is formed downwind by photochemical reaction of NO<sub>x</sub> and VOCs in certain ambient conditions.

The graphed data shown in Figures 3 through 5 present measured concentrations for these pollutants collected during the monitoring period relative to the Baseline concentration and NAAQS Standard.

The NAAQS for NO<sub>2</sub>, PM<sub>2.5</sub>, and PM<sub>10</sub> were not exceeded during the monitoring period addressed in this report.

Electronic records of all data and calibrations have been uploaded to the Montrose Data Server, where they will be archived for a period of at least three (3) years.



## Meteorological Data Collected

Figures 2-A and 2-B present wind roses derived from the meteorological data collected from each of the two monitors operated at the former State Fairgrounds over the course of the monitoring period of 11/3/23 to 11/12/23.

**Figure 2-A – Wind Rose From 1838 Monitor**





Figure 2-B – Wind Rose From 1839 Monitor



As is evident from the wind rose data, predominant winds were from the west during the monitoring period. Wind speeds recorded at monitors 1838 and 1839 were generally very light to medium.


## Pollutant Data Collected

**Figure 3 – PM<sub>10</sub> Data**

Monitoring at the Upwind site location (AQS-1 S/N 1838) commenced on 11/3/23. Monitoring at the Downwind site location (AQS-1 S/N 1839) also commenced on 11/3/23. Concurrent monitoring at both locations satisfied the (minimum) one-week Post-Construction monitoring period requirement.

The graph below represents the ambient PM<sub>10</sub> measurement data collected at the former Michigan State Fairgrounds property during the monitoring period of 11/3/23 to 11/12/23. This graph is a plot of the PM<sub>10</sub> measurement data as averaged over each daily monitoring period. The daily averaging interval for PM<sub>10</sub> data is consistent with the associated EPA primary and secondary PM<sub>10</sub> NAAQS; a 24-hour (daily) averaged value of 150 micrograms per cubic meter ( $\mu\text{g}/\text{m}^3$ ) not to be exceeded more than once per year on average over 3 years.

The solid yellow line represents the 24-hour PM<sub>10</sub> NAAQS of 150  $\mu\text{g}/\text{m}^3$ . The solid red line represents the baseline concentration established in the 1<sup>st</sup> Baseline Report. The PM<sub>10</sub> monitor at the EGLE Dearborn Site is the closest state-operated PM<sub>10</sub> monitor relative to the former Michigan State Fairgrounds property. Therefore, the graph below presents the 24-hour averaged data from the EGLE Dearborn continuous PM<sub>10</sub> monitor for comparison to corresponding PM<sub>10</sub> measurement data reported from the on-site monitors.






**Figure 4 – PM<sub>2.5</sub> Data**

Monitoring at the Upwind site location (AQS-1 S/N 1838) commenced on 11/3/23. Monitoring at the Downwind site location (AQS-1 S/N 1839) also commenced on 11/3/23. Concurrent monitoring at both locations satisfied the (minimum) one-week Post-Construction monitoring period requirement.

The graph below represents the ambient PM<sub>2.5</sub> measurement data collected at the former Michigan State Fairgrounds property during the monitoring period of 11/3/23 to 11/12/23. This graph is a plot of the PM<sub>2.5</sub> measurement data as averaged over each daily monitoring period. The daily averaging interval for PM<sub>2.5</sub> data is consistent with the associated EPA primary and secondary PM<sub>2.5</sub> NAAQS: A 24-hour (daily) averaged value of 35 micrograms per cubic meter (µg/m<sup>3</sup>) not to be exceeded more than once per year on average over 3 years.

The solid yellow line represents the 24-hour PM<sub>2.5</sub> NAAQS of 35 µg/m<sup>3</sup>. The solid red line represents the baseline concentration established in the 1<sup>st</sup> Baseline Report. The EGLE Oak Park monitoring Site is the nearest state-operated PM<sub>2.5</sub> monitor relative to the former Michigan State Fairgrounds property. The EGLE Oak Park PM<sub>2.5</sub> monitor is a 24-hour, filter-based sampler that collects a sample at 3-day intervals. Filter-based PM samples require gravimetric analysis at a laboratory; EGLE estimates that analytical results for the Oak Park PM<sub>2.5</sub> filters are delayed on average by approximately three months. Therefore, the graph below presents the 24-hour averaged data from the EGLE Dearborn and EGLE DET-SW continuous PM<sub>2.5</sub> monitors for comparison to corresponding PM<sub>2.5</sub> measurement data reported from the on-site monitors.




**Figure 5 – NO<sub>2</sub> Data**

Monitoring at the Upwind site location (AQS-1 S/N 1838) commenced on 11/3/23. Monitoring at the Downwind site location (AQS-1 S/N 1839) also commenced on 11/3/23. Concurrent monitoring at both locations satisfied the (minimum) one-week Post-Construction monitoring period requirement.

The graph below represents the ambient NO<sub>2</sub> measurement data collected at the former Michigan State Fairgrounds property during the monitoring period of 11/3/23 to 11/12/23. This graph is a plot of the NO<sub>2</sub> measurement data as averaged over a period of one (1) hour. This is consistent with the associated EPA primary NO<sub>2</sub> NAAQS: A 1-hour averaged value of 100 parts-per-billion (ppb) not to be exceeded more than once per year on average over 3 years.


The solid yellow line represents the 1-hour NO<sub>2</sub> NAAQS of 100 ppb. The solid red line represents the baseline concentration established in the 1<sup>st</sup> Baseline Report. The NO<sub>2</sub> monitor at the EGLE DET-SW site is the closest state-operated NO<sub>2</sub> monitor relative to the former Michigan State Fairgrounds property. The graph below presents the 1-hour averaged data from the EGLE DET-SW continuous NO<sub>2</sub> monitor for comparison to corresponding NO<sub>2</sub> measurement data reported from the on-site monitors.



**Figure 6 – VOC Data**

Monitoring at the Upwind site location (AQS-1 S/N 1838) commenced on 11/3/23. Monitoring at the Downwind site location (AQS-1 S/N 1839) also commenced on 11/3/23. Concurrent monitoring at both locations satisfied the (minimum) one-week Post-Construction monitoring period requirement.

The graph below presents the ambient VOC measurement data collected at the former Michigan State Fairgrounds property during the monitoring period of 11/3/23 to 11/12/23. This graph is a plot of the VOC measurement data as averaged over a period of one (1) hour. The solid red line represents the baseline concentration established in the 1<sup>st</sup> Baseline Report. The EPA has not established a NAAQS for VOC. VOC data are not available from nearby EGLE monitoring Sites.



## Data Quality Assurance/Quality Control

### Quality Assurance/Quality Control


Quality assurance is a general term for the procedures used to ensure that a particular measurement meets the quality requirements for its intended use. Quality control of continuous analyzers consists of precision and span checks or flow verifications. Quality objectives were assessed via Site system audits.

All work performed by Montrose in support of this project follows the operating and quality control procedures contained in the Post-Construction Ambient Air Test Plan for the Amazon Fulfillment Center at the Former Michigan State Fairgrounds dated 1/31/23.

All quality control test data for the on-site monitors operated at the former Michigan State Fairgrounds property can be found in Appendix A to this report entitled "*Quality Assurance Logs*". Certificates of traceability for the calibration standards and equipment used in support of quality assurance checks are presented in Appendix B to this report entitled "*Calibration Certification Sheets*".

## Signature Page


Prepared by:



---

Linda Quigley  
Senior Reporting QC Specialist  
Montrose Air Quality Services LLC

Reviewed by:



---

David Cummings  
District Manager  
Montrose Air Quality Services LLC

## **Appendix**

### ***A: Quality Assurance Logs***

**AEROQUAL AQS-1 VOC HIGH RANGE MODULE VERIFICATION/CALIBRATION FORM**

Network:	City of Detroit (Amazon)	Site:	MTMS Lab	Date:	10/31/23
Time Off-Line:	11:49 EST	Time On-Line:	14:11 EST	Technician:	Jeremy Levine

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1838	Last Cal:	9/27/23
	Calibrator Model No:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	AirGas	Cyl. Conc. (PPM):	49.33	Cyl. Pressure (PSIG)	2,060

VOC Sensor Module Calibration Settings	"As Found" (Before Any Adjustment)	"As Left" (After Adjustment)
OFFSET	0.00	
GAIN	1.389	

**"AS FOUND" (UNADJUSTED) TEST DATA**

Calibrator Flow and Test Gas Data					Observed VOC Response from AQS-1		Error (Δ%)
Calibrator Gas Channel		Calibrator Air Channel		Known VOC Input Gas Conc. (PPM)	Response (PPM)	Std. Dev. (PPM)	
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)				
OFF	OFF	5.0000	5.0153	0.00	0.00	0.00	-
0.0500	0.0502	4.9493	4.9741	0.49	0.50	0.00	2.0%
0.0500	0.0501	4.4493	2.4688	0.98	0.94	0.00	-4.1%

**"AS LEFT" (ADJUSTED) TEST DATA**

Calibrator Flow and Test Gas Data					Observed VOC Response from AQS-1		Error (Δ%)
Calibrator Gas Channel		Calibrator Air Channel		Known VOC Input Gas Conc. (PPM)	Response (PPM)	Std. Dev. (PPM)	
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)				
OFF	OFF	5.0000		0.00			-


**NOTES:**

- The VOC sensor zero response should be 0.0 ppm ± 0.2 ppm with a Std. Dev. < 0.2 ppm. If the sensor response error is greater than ± 0.2 ppm then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppm then the sensor is outside acceptable range and may need replacement.
- The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppm ± 0.2 ppm.
- The VOC sensor SPAN response should be ± 1 ppm (5% span of 20 ppm) with a Std. Dev. < 0.4 ppm (2% span of 20 ppm). If the sensor response error is greater than ± 1 ppm then a GAIN adjustment is required. If the Std. Dev. is greater than 0.4 ppm then the sensor is outside acceptable range and may need replacement.
- The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 0.0 ppm ± 1 ppm.

**Comments:**

Values good, no adjustment needed.

Technician: Jeremy Levine

QA Review: 

**MONTROSE AIR QUALITY SERVICES LLC**

**AEROQUAL AQS-1 NO2 MODULE MULTI-POINT CALIBRATION FORM**

Calibration Data on This Form Are For:				Unadjusted Cal.	X	Adjusted Cal.	
Network:	City of Detroit (Amazon)	Site:	MTMS Lab	Date:	10/31/23		
Time Off-Line:	14:13 EST	Time On-Line:	19:57 EST	Technician:	Jeremy Levine		

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1838	Last Cal:	9/27/23
	Calibrator Model No.:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No.:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	Airgas	Cyl. Cert. Date:	1/26/21	Cyl. Pressure (PSIG)	1,300
	Gas Cylinder ID #:	D068357	Cyl. Conc. (PPM):	30.95	Gas Module Total Flow Rate	130 mL

<b>Analyzer Calibration Settings</b>	<b>"As Found" (Before Any Adjustment)</b>	<b>"As Left" (After Adjustment)</b>
OFFSET	-0.6	-0.6
GAIN	1.213	1.310

Calibrator Flow and Test Gas Data					NO <sub>2</sub> Response		Δ% (Observed Response Vs. Known Conc.) 3	PASS/FAIL
Calibrator Gas Channel		Calibrator Air Channel		Known NO <sub>2</sub> Gas Conc. (PPB)	Observed from AQS-1			
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)			Response (PPB)	Std. Dev. (PPB)	
0.0452	0.0453	3.4548	3.4780	397.9	368.4	0.2	-7.4%	
0.0484	0.0485	4.9516	4.9776	298.7	277.5	0.6	-7.1%	
0.0323	0.0324	4.9677	4.9928	199.6	186.7	0.9	-6.5%	
0.0161	0.0163	4.9839	5.0093	100.4	92.5	0.4	-7.9%	
OFF	OFF	5.0000	5.0179	0.0	0.6	0.2	-	

Linear Regression Analysis:					
Slope:	0.926064	Intercept:	0.557010	Corr. Coefficient (r):	0.999981

**NOTES:**

- The NO<sub>2</sub> sensor zero response should be 0.0 ppb ± 0.2 ppb with a Std. Dev. < 0.2 ppb. If the sensor response error is greater than ± 0.2 ppb then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppb ± 0.2 ppb.
- The NO<sub>2</sub> sensor SPAN response should be 400 ppb ± 20 ppb (5% span of 400 ppb) with a Std. Dev. < 8 ppb (2% span of 400 ppb). If the sensor response error is greater than ±20 ppb then a GAIN adjustment is required. If the Std. Dev. is greater than 8.0 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 400 ppb ± 20 ppb.

**Comments:**

--

Technician: Jeremy Levine

QA Review: 

**MONTROSE AIR QUALITY SERVICES LLC**



**AEROQUAL AQS-1 NO2 MODULE MULTI-POINT CALIBRATION FORM**

Calibration Data on This Form Are For:				Unadjusted Cal.		Adjusted Cal.	<b>X</b>
Network:	City of Detroit (Amazon)	Site:	MTMS Lab	Date:	10/31/23		
Time Off-Line:	14:13 EST	Time On-Line:	19:57 EST	Technician:	Jeremy Levine		

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1838	Last Cal:	9/27/23
	Calibrator Model No.:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No.:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	Airgas	Cyl. Cert. Date:	1/26/21	Cyl. Pressure (PSIG)	1,380
	Gas Cylinder ID #:	D068357	Cyl. Conc. (PPM):	30.95	Gas Module Total Flow Rate	130 mL

<b>Analyzer Calibration Settings</b>	<b>"As Found" (Before Any Adjustment)</b>	<b>"As Left" (After Adjustment)</b>
<b>OFFSET</b>	-0.6	-0.6
<b>GAIN</b>	1.213	1.310

Calibrator Flow and Test Gas Data					NO <sub>2</sub> Response		Δ% (Observed Response Vs. Known Conc.) 3	PASS/FAIL
Calibrator Gas Channel		Calibrator Air Channel		Known NO <sub>2</sub> Gas Conc. (PPB)	<i>Observed from AQS-1</i>			
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)			Response (PPB)	Std. Dev. (PPB)	
0.0452	0.0453	3.4548	3.4788	397.8	394.1	0.4	-0.9%	
0.0484	0.0486	4.9516	4.9779	299.2	298.2	0.7	-0.3%	
0.0323	0.0324	4.9677	4.9921	199.6	196.8	0.5	-1.4%	
0.0161	0.0163	4.9839	5.0104	100.4	99.3	0.6	-1.1%	
OFF	OFF	5.0000	5.0147	0.0	0.9	0.8	-	

Linear Regression Analysis:					
Slope:	0.990848	Intercept:	0.284936	Corr. Coefficient (r):	0.999977

**NOTES:**

1. The NO<sub>2</sub> sensor zero response should be 0.0 ppb ± 0.2 ppb with a Std. Dev. < 0.2 ppb. If the sensor response error is greater than ± 0.2 ppb then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppb then the sensor is outside acceptable range and may need replacement.
2. The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppb ± 0.2 ppb.
3. The NO<sub>2</sub> sensor SPAN response should be 400 ppb ± 20 ppb (5% span of 400 ppb) with a Std. Dev. < 8 ppb (2% span of 400 ppb). If the sensor response error is greater than ±20 ppb then a GAIN adjustment is required. If the Std. Dev. is greater than 8.0 ppb then the sensor is outside acceptable range and may need replacement.
4. The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 400 ppb ± 20 ppb.

**Comments:**

--

Technician: Jeremy Levine

QA Review: 

**MONTROSE AIR QUALITY SERVICES LLC**



**AEROQUAL AQS-1 VOC HIGH RANGE MODULE VERIFICATION/CALIBRATION FORM**

Network:	City of Detroit (Amazon)	Site:	MTMS Lab	Date:	11/14/23
Time Off-Line:	12:48 EST	Time On-Line:	15:08 EST	Technician:	Jeremy Levine

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1838	Last Cal:	10/31/23
	Calibrator Model No:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	AirGas	Cyl. Conc. (PPM):	49.33	Cyl. Pressure (PSIG)	2,050

VOC Sensor Module Calibration Settings	"As Found" (Before Any Adjustment)	"As Left" (After Adjustment)
OFFSET	0.00	
GAIN	1.389	

**"AS FOUND" (UNADJUSTED) TEST DATA**

Calibrator Flow and Test Gas Data					Observed VOC Response from AQS-1		Error (Δ%)
Calibrator Gas Channel		Calibrator Air Channel		Known VOC Input Gas Conc. (PPM)	Response (PPM)	Std. Dev. (PPM)	
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)				
OFF	OFF	5.0000	5.0174	0.00	0.00	0.00	-
0.0500	0.0502	4.9439	4.9742	0.49	0.51	0.00	4.1%
0.0500	0.0501	2.4493	2.4672	0.98	0.95	0.00	-3.1%

**"AS LEFT" (ADJUSTED) TEST DATA**

Calibrator Flow and Test Gas Data					Observed VOC Response from AQS-1		Error (Δ%)
Calibrator Gas Channel		Calibrator Air Channel		Known VOC Input Gas Conc. (PPM)	Response (PPM)	Std. Dev. (PPM)	
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)				
OFF	OFF	5.0000		0.00			-


**NOTES:**

1. The VOC sensor zero response should be 0.0 ppm ± 0.2 ppm with a Std. Dev. < 0.2 ppm. If the sensor response error is greater than ± 0.2 ppm then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppm then the sensor is outside acceptable range and may need replacement.
2. The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppm ± 0.2 ppm.
3. The VOC sensor SPAN response should be ± 1 ppm (5% span of 20 ppm) with a Std. Dev. < 0.4 ppm (2% span of 20 ppm). If the sensor response error is greater than ± 1 ppm then a GAIN adjustment is required. If the Std. Dev. is greater than 0.4 ppm then the sensor is outside acceptable range and may need replacement.
4. The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 0.0 ppm ± 1 ppm.

**Comments:**

Values good, no adjustment needed.

Technician: Jeremy Levine

QA Review: 

**MONTROSE AIR QUALITY SERVICES LLC**

**AEROQUAL AQS-1 NO2 MODULE MULTI-POINT CALIBRATION FORM**

Calibration Data on This Form Are For:				Unadjusted Cal.	X	Adjusted Cal.	
Network:	City of Detroit (Amazon)	Site:	MTMS Lab	Date:	11/14/23		
Time Off-Line:	15:09 EST	Time On-Line:	18:09 EST	Technician:	Jeremy Levine		

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1838	Last Cal:	10/31/23
	Calibrator Model No.:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No.:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	Airgas	Cyl. Cert. Date:	1/26/21	Cyl. Pressure (PSIG)	1,290
	Gas Cylinder ID #:	D068357	Cyl. Conc. (PPM):	30.95	Gas Module Total Flow Rate	130 mL

<b>Analyzer Calibration Settings</b>	<b>"As Found" (Before Any Adjustment)</b>	<b>"As Left" (After Adjustment)</b>
OFFSET	-0.6	
GAIN	1.310	

Calibrator Flow and Test Gas Data					NO <sub>2</sub> Response		Δ% (Observed Response Vs. Known Conc.) 3	PASS/FAIL
Calibrator Gas Channel		Calibrator Air Channel		Known NO <sub>2</sub> Gas Conc. (PPB)	Observed from AQS-1			
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)			Response (PPB)	Std. Dev. (PPB)	
0.0452	0.0453	3.4548	3.4775	398.0	395.4	1.0	-0.7%	
0.0484	0.0485	4.9516	4.9791	298.6	300.0	0.4	0.5%	
0.0323	0.0324	4.9677	4.9918	199.6	197.1	0.3	-1.3%	
0.0161	0.0162	4.9839	5.0078	99.8	100.1	0.8	0.3%	
OFF	OFF	5.0000	5.0164	0.0	-0.3	0.2	-	

Linear Regression Analysis:					
Slope:	0.996476	Intercept:	-0.037950	Corr. Coefficient (r):	0.999943

**NOTES:**

- The NO<sub>2</sub> sensor zero response should be 0.0 ppb ± 0.2 ppb with a Std. Dev. < 0.2 ppb. If the sensor response error is greater than ± 0.2 ppb then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppb ± 0.2 ppb.
- The NO<sub>2</sub> sensor SPAN response should be 400 ppb ± 20 ppb (5% span of 400 ppb) with a Std. Dev. < 8 ppb (2% span of 400 ppb). If the sensor response error is greater than ±20 ppb then a GAIN adjustment is required. If the Std. Dev. is greater than 8.0 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 400 ppb ± 20 ppb.

**Comments:**

Values goede, no adjustment needed.

Technician: Jeremy Levine

QA Review: 

**MONTROSE AIR QUALITY SERVICES LLC**

# AEROQUAL AQS-1 FLOW and LEAK CHECK FORM

QC Checks are:  Scheduled                         (If unscheduled, explain reason why in "Comments" Section)

<b>Network:</b>	City of Detroit (Transit)	<b>Site:</b>	Fairgrounds
		<b>Date of Checks:</b>	7/14/2023
<b>Operator:</b>	Jeremy Levine, Jeff Peitzsch	<b>Time Off-Line:</b>	EST
<b>AEROQUAL QS-1 S/N:</b>	1838	<b>Time On-Line:</b>	EST

**Reference Standards:**

<b>Flow Standard:</b>	Aeroqual Rotometer	<b>S/N#</b>	n/a	<b>Cert Date:</b>	n/a
-----------------------	--------------------	-------------	-----	-------------------	-----

**AS FOUND CHECK DATA**

Checks are "as found" checks. Adjust profiler flow or resolve leak and complete "as left" section below if any acceptability limits are exceeded or if any adjustments to the monitor are to be made.

**FLOW CHECK DATA:**

AQS-1 Expected Flow Rate (A)	Reference Flow Rate (B)	Profiler Flow Rate Error LPM (A-B)	Profiler Flow Rate Error Δ% (A-B) ÷ A x 100
1.0 LPM	1.00 LPM	0.00	0.0%

[Flow Check Procedure Link](#)

**Acceptability Limits: The expected AQS-1 Particle Profiler Flow Rate is 1.0 LPM ± 0.05 LPM (between 0.95 LPM and 1.05 LPM) or ±5%.**

**LEAK CHECK DATA:**

<b>PROFILER LEAKAGE RATE:</b>	30 seconds	(Must be >10 sec for 10 kPa pressure change)
-------------------------------	------------	--

[Leak Check Procedure Link](#)

**AS LEFT CHECK DATA**

**FLOW CHECK DATA:**

AQS-1 Expected Flow Rate (A)	Reference Flow Rate (B)	Profiler Flow Rate Error LPM	Profiler Flow Rate Error Δ%
LPM	LPM		

**LEAK CHECK DATA:**

<b>PROFILER LEAKAGE RATE:</b>	seconds	(Must be > 10 sec for 10 kPa pressure change)
-------------------------------	---------	---

Comments:

Technician: Jeremy Levine

QA Review:

**MONTROSE AIR QUALITY SERVICES LLC**

**AEROQUAL AQS-1 VOC HIGH RANGE MODULE VERIFICATION/CALIBRATION FORM**

Network:	City of Detroit (Amazon)	Site:	MTMS Lab	Date:	10/31/23
Time Off-Line:	11:49 EST	Time On-Line:	14:11 EST	Technician:	Jeremy Levine

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1839	Last Cal:	9/27/23
	Calibrator Model No:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	AirGas	Cyl. Conc. (PPM):	49.33	Cyl. Pressure (PSIG)	2,060

VOC Sensor Module Calibration Settings	"As Found" (Before Any Adjustment)	"As Left" (After Adjustment)
OFFSET	0.00	0.00
GAIN	1.573	1.643

**"AS FOUND" (UNADJUSTED) TEST DATA**

Calibrator Flow and Test Gas Data					Observed VOC Response from AQS-1		Error (Δ%)
Calibrator Gas Channel		Calibrator Air Channel		Known VOC Input Gas Conc. (PPM)	Response (PPM)	Std. Dev. (PPM)	
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)				
OFF	OFF	5.0000	5.0153	0.00	0.00	0.00	-
0.0500	0.0502	4.9493	4.9741	0.49	0.49	0.00	0.0%
0.0500	0.0501	4.4493	2.4688	0.98	0.90	0.00	-8.2%

**"AS LEFT" (ADJUSTED) TEST DATA**


Calibrator Flow and Test Gas Data					Observed VOC Response from AQS-1		Error (Δ%)
Calibrator Gas Channel		Calibrator Air Channel		Known VOC Input Gas Conc. (PPM)	Response (PPM)	Std. Dev. (PPM)	
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)				
OFF	OFF	5.0000	5.0137	0.00	0.00	0.0	-
0.0500	0.0502	4.9493	4.9760	0.49	0.52	0.0	6.1%
0.0500	0.0501	2.4493	2.4690	0.98	0.95	0.0	-3.1%

**NOTES:**

- The VOC sensor zero response should be 0.0 ppm ± 0.2 ppm with a Std. Dev. < 0.2 ppm. If the sensor response error is greater than ± 0.2 ppm then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppm then the sensor is outside acceptable range and may need replacement.
- The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppm ± 0.2 ppm.
- The VOC sensor SPAN response should be ± 1 ppm (5% span of 20 ppm) with a Std. Dev. < 0.4 ppm (2% span of 20 ppm). If the sensor response error is greater than ± 1 ppm then a GAIN adjustment is required. If the Std. Dev. is greater than 0.4 ppm then the sensor is outside acceptable range and may need replacement.
- The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 0.0 ppm ± 1 ppm.

**Comments:**

Technician: Jeremy Levine

QA Review: 

**MONTROSE AIR QUALITY SERVICES LLC**

**AEROQUAL AQS-1 NO2 MODULE MULTI-POINT CALIBRATION FORM**

Calibration Data on This Form Are For:				Unadjusted Cal.	X	Adjusted Cal.	
Network:	City of Detroit (Amazon)		Site:	MTMS Lab		Date:	10/31/23
Time Off-Line:	14:13 EST	Time On-Line:	19:57 EST		Technician:	Jeremy Levine	

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1839	Last Cal:	9/27/23
	Calibrator Model No.:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No.:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	Airgas	Cyl. Cert. Date:	1/26/21	Cyl. Pressure (PSIG)	1,300
	Gas Cylinder ID #:	D068357	Cyl. Conc. (PPM):	30.95	Gas Module Total Flow Rate	130 mL

<b>Analyzer Calibration Settings</b>	<b>"As Found" (Before Any Adjustment)</b>	<b>"As Left" (After Adjustment)</b>
OFFSET	0.0	0.0
GAIN	1.144	1.255

Calibrator Flow and Test Gas Data					NO <sub>2</sub> Response <i>Observed from AQS-1</i>		Δ% (Observed Response Vs. Known Conc.) 3	PASS/FAIL
Calibrator Gas Channel		Calibrator Air Channel		Known NO <sub>2</sub> Gas Conc. (PPB)	Response (PPB)	Std. Dev. (PPB)		
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)					
0.0452	0.0453	3.4548	3.4780	397.9	362.6	0.6	-8.9%	
0.0484	0.0485	4.9516	4.9776	298.7	272.0	0.5	-8.9%	
0.0323	0.0324	4.9677	4.9928	199.6	182.5	0.2	-8.6%	
0.0161	0.0163	4.9839	5.0093	100.4	89.1	0.6	-11.3%	
OFF	OFF	5.0000	5.0179	0.0	-0.4	0.4	-	

<b>Linear Regression Analysis:</b>			
Slope:	0.914286	Intercept:	-1.075537
		Corr. Coefficient (r):	0.999974


**NOTES:**

- The NO2 sensor zero response should be 0.0 ppb ± 0.2 ppb with a Std. Dev. < 0.2 ppb. If the sensor response error is greater than ± 0.2 ppb then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppb ± 0.2 ppb.
- The NO2 sensor SPAN response should be 400 ppb ± 20 ppb (5% span of 400 ppb) with a Std. Dev. < 8 ppb (2% span of 400 ppb). If the sensor response error is greater than ±20 ppb then a GAIN adjustment is required. If the Std. Dev. is greater than 8.0 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 400 ppb ± 20 ppb.

**Comments:**

--

Technician: Jeremy Levine

QA Review: 

**MONTROSE AIR QUALITY SERVICES LLC**

**AEROQUAL AQS-1 NO2 MODULE MULTI-POINT CALIBRATION FORM**

Calibration Data on This Form Are For:				<b>Unadjusted Cal.</b>		<b>Adjusted Cal.</b>	<b>X</b>
Network:	City of Detroit (Amazon)	Site:	MTMS Lab	Date:	10/31/23		
Time Off-Line:	14:13 EST	Time On-Line:	19:57 EST	Technician:	Jeremy Levine		

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1839	Last Cal:	9/27/23
	Calibrator Model No.:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No.:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	Airgas	Cyl. Cert. Date:	1/26/21	Cyl. Pressure (PSIG)	1,380
	Gas Cylinder ID #:	D068357	Cyl. Conc. (PPM):	30.95	Gas Module Total Flow Rate	130 mL

<b>Analyzer Calibration Settings</b>	<b>"As Found" (Before Any Adjustment)</b>	<b>"As Left" (After Adjustment)</b>
<b>OFFSET</b>	0.0	0.0
<b>GAIN</b>	1.144	1.255

Calibrator Flow and Test Gas Data					NO <sub>2</sub> Response		Δ% (Observed Response Vs. Known Conc.) 3	PASS/FAIL
Calibrator Gas Channel		Calibrator Air Channel		Known NO <sub>2</sub> Gas Conc. (PPB)	Observed from AQS-1			
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)		Response (PPB)	Std. Dev. (PPB)		
0.0452	0.0453	3.4548	3.4788	397.8	395.7	0.4	-0.5%	
0.0484	0.0486	4.9516	4.9779	299.2	299.5	0.6	0.1%	
0.0323	0.0324	4.9677	4.9921	199.6	197.1	0.3	-1.3%	
0.0161	0.0163	4.9839	5.0104	100.4	98.1	0.9	-2.3%	
OFF	OFF	5.0000	5.0147	0.0	0.2	0.4	-	

<b>Linear Regression Analysis:</b>			
Slope:	0.997984	Intercept:	-0.877949
		Corr. Coefficient (r):	0.999962


**NOTES:**

- The NO<sub>2</sub> sensor zero response should be 0.0 ppb ± 0.2 ppb with a Std. Dev. < 0.2 ppb. If the sensor response error is greater than ± 0.2 ppb then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppb ± 0.2 ppb.
- The NO<sub>2</sub> sensor SPAN response should be 400 ppb ± 20 ppb (5% span of 400 ppb) with a Std. Dev. < 8 ppb (2% span of 400 ppb). If the sensor response error is greater than ±20 ppb then a GAIN adjustment is required. If the Std. Dev. is greater than 8.0 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 400 ppb ± 20 ppb.

**Comments:**

--

Technician: Jeremy Levine

QA Review: 

**MONTROSE AIR QUALITY SERVICES LLC**





**AEROQUAL AQS-1 VOC HIGH RANGE MODULE VERIFICATION/CALIBRATION FORM**

Network:	City of Detroit (Amazon)	Site:	MTMS Lab	Date:	11/14/23
Time Off-Line:	12:48 EST	Time On-Line:	15:08 EST	Technician:	Jeremy Levine

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1839	Last Cal:	10/31/23
	Calibrator Model No:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	AirGas	Cyl. Conc. (PPM):	49.33	Cyl. Pressure (PSIG)	2,050

VOC Sensor Module Calibration Settings	"As Found" (Before Any Adjustment)	"As Left" (After Adjustment)
OFFSET	0.00	0.00
GAIN	1.643	1.457

**"AS FOUND" (UNADJUSTED) TEST DATA**

Calibrator Flow and Test Gas Data					Observed VOC Response from AQS-1		Error (Δ%)
Calibrator Gas Channel		Calibrator Air Channel		Known VOC Input Gas Conc. (PPM)	Response (PPM)	Std. Dev. (PPM)	
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)				
OFF	OFF	5.0000	5.0174	0.00	0.00	0.00	-
0.0500	0.0502	4.9439	4.9742	0.49	0.57	0.00	16.3%
0.0500	0.0501	2.4493	2.4672	0.98	1.04	0.00	6.1%

**"AS LEFT" (ADJUSTED) TEST DATA**

Calibrator Flow and Test Gas Data					Observed VOC Response from AQS-1		Error (Δ%)
Calibrator Gas Channel		Calibrator Air Channel		Known VOC Input Gas Conc. (PPM)	Response (PPM)	Std. Dev. (PPM)	
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)				
OFF	OFF	5.0000	5.0175	0.00	0.00	0.0	-
0.0500	0.0502	4.9493	4.9761	0.49	0.51	0.0	4.1%
0.0500	0.0502	2.4493	2.4694	0.98	0.93	0.0	-5.1%

**NOTES:**

- The VOC sensor zero response should be 0.0 ppm ± 0.2 ppm with a Std. Dev. < 0.2 ppm. If the sensor response error is greater than ± 0.2 ppm then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppm then the sensor is outside acceptable range and may need replacement.
- The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppm ± 0.2 ppm.
- The VOC sensor SPAN response should be ± 1 ppm (5% span of 20 ppm) with a Std. Dev. < 0.4 ppm (2% span of 20 ppm). If the sensor response error is greater than ± 1 ppm then a GAIN adjustment is required. If the Std. Dev. is greater than 0.4 ppm then the sensor is outside acceptable range and may need replacement.
- The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 0.0 ppm ± 1 ppm.

**Comments:**

Technician: Jeremy Levine

QA Review: 

**MONTROSE AIR QUALITY SERVICES LLC**

**AEROQUAL AQS-1 NO2 MODULE MULTI-POINT CALIBRATION FORM**

Calibration Data on This Form Are For:				Unadjusted Cal.	X	Adjusted Cal.	
Network:	City of Detroit (Amazon)		Site:	MTMS Lab		Date:	11/14/23
Time Off-Line:	15:09 EST	Time On-Line:	18:09 EST		Technician:	Jeremy Levine	

<b>Calibration Equipment Info.</b>	Analyzer Model:	Aeroqual AQS-1	S/N:	1839	Last Cal:	10/31/23
	Calibrator Model No.:	Teledyne API	S/N:	69	Cal. Date:	3/2/23
	Zero Air Model No.:	Teledyne API	S/N:	n/a	Cert Date:	n/a
	Gas Supplier:	Airgas	Cyl. Cert. Date:	1/26/21	Cyl. Pressure (PSIG)	1,290
	Gas Cylinder ID #:	D068357	Cyl. Conc. (PPM):	30.95	Gas Module Total Flow Rate	130 mL

<b>Analyzer Calibration Settings</b>	<b>"As Found" (Before Any Adjustment)</b>	<b>"As Left" (After Adjustment)</b>
OFFSET	0.0	
GAIN	1.255	

Calibrator Flow and Test Gas Data					NO <sub>2</sub> Response		Δ% (Observed Response Vs. Known Conc.) 3	PASS/FAIL
Calibrator Gas Channel		Calibrator Air Channel		Known NO <sub>2</sub> Gas Conc. (PPB)	Observed from AQS-1			
Display Setting (SLPM)	Actual Flow Rate (SLPM)	Display Setting (SLPM)	Actual Flow Rate (SLPM)			Response (PPB)	Std. Dev. (PPB)	
0.0452	0.0453	3.4548	3.4775	398.0	412.2	0.7	3.6%	
0.0484	0.0485	4.9516	4.9791	298.6	313.3	0.5	4.9%	
0.0323	0.0324	4.9677	4.9918	199.6	207.9	0.3	4.2%	
0.0161	0.0162	4.9839	5.0078	99.8	103.6	0.5	3.8%	
OFF	OFF	5.0000	5.0164	0.0	0.1	1.0	-	

Linear Regression Analysis:					
Slope:	1.039306	Intercept:	0.390281	Corr. Coefficient (r):	0.999952


**NOTES:**

- The NO<sub>2</sub> sensor zero response should be 0.0 ppb ± 0.2 ppb with a Std. Dev. < 0.2 ppb. If the sensor response error is greater than ± 0.2 ppb then an offset adjustment is required. If the Std. Dev. is greater than 0.2 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted zero response NEW offset should be -1 < OFFSET < 1 and the sensor response 0.0 ppb ± 0.2 ppb.
- The NO<sub>2</sub> sensor SPAN response should be 400 ppb ± 20 ppb (5% span of 400 ppb) with a Std. Dev. < 8 ppb (2% span of 400 ppb). If the sensor response error is greater than ±20 ppb then a GAIN adjustment is required. If the Std. Dev. is greater than 8.0 ppb then the sensor is outside acceptable range and may need replacement.
- The adjusted span response NEW gain should be 0.2 < GAIN < 5.0 and the sensor response 400 ppb ± 20 ppb.

**Comments:**

Results acceptable, no adjustment needed.

Technician: Jeremy Levine

QA Review: 

## AEROQUAL AQS-1 FLOW and LEAK CHECK FORM

QC Checks are:  Scheduled                                      Unscheduled (If unscheduled, explain reason why in "Comments" Section)

<b>Network:</b>	City of Detroit (Transit)	<b>Site:</b>	Fairgrounds	<b>Date of Checks:</b>	11/14/2023
<b>Operator:</b>	Rob Bienenstein	<b>Time Off-Line:</b>	n/a		EST
<b>AEROQUAL QS-1 S/N:</b>	1839	<b>Time On-Line:</b>	n/a		EST

**Reference Standards:**

<b>Flow Standard:</b>	Aeroqual Rotometer	<b>S/N#</b>	n/a	<b>Cert Date:</b>	n/a
-----------------------	--------------------	-------------	-----	-------------------	-----

**AS FOUND CHECK DATA**

Checks are "as found" checks. Adjust profiler flow or resolve leak and complete "as left" section below if any acceptability limits are exceeded or if any adjustments to the monitor are to be made.

**FLOW CHECK DATA:**

AQS-1 Expected Flow Rate (A)	Reference Flow Rate (B)	Profiler Flow Rate Error LPM (A-B)	Profiler Flow Rate Error Δ% (A-B) ÷ A x 100
1.0 LPM	1.00 LPM	0.00	0.0%

[Flow Check Procedure Link](#)

**Acceptability Limits: The expected AQS-1 Particle Profiler Flow Rate is 1.0 LPM ± 0.05 LPM (between 0.95 LPM and 1.05 LPM) or ≤±5%.**

**LEAK CHECK DATA:**

<b>PROFILER LEAKAGE RATE:</b>	30 seconds	(Must be >10 sec for 10 kPa pressure change)
-------------------------------	------------	--

[Leak Check Procedure Link](#)

**AS LEFT CHECK DATA**

**FLOW CHECK DATA:**

AQS-1 Expected Flow Rate (A)	Reference Flow Rate (B)	Profiler Flow Rate Error LPM	Profiler Flow Rate Error Δ%
LPM	LPM		

**LEAK CHECK DATA:**

<b>PROFILER LEAKAGE RATE:</b>	seconds	(Must be > 10 sec for 10 kPa pressure change)
-------------------------------	---------	---

Comments:

Technician: Rob Bienenstein

QA Review: *Keimbergstein*

**MONTROSE AIR QUALITY SERVICES LLC**

***B: Calibration Certification Sheets***

## CERTIFICATE OF ANALYSIS

### Grade of Product: CERTIFIED STANDARD-SPEC

Part Number:	X02NI99C15A0104	Reference Number:	141-402072346-1
Cylinder Number:	EB0112566	Cylinder Volume:	144.4 CF
Laboratory:	124 - Stryker (SAP) - OH	Cylinder Pressure:	2015 PSIG
Analysis Date:	Mar 31, 2021	Valve Outlet:	350
Lot Number:	141-402072346-1		

Product composition verified by direct comparison to calibration standards traceable to N.I.S.T. weights and/or N.I.S.T. Gas Mixture reference materials.

### ANALYTICAL RESULTS

Component	Req Conc	Actual Concentration (Mole %)	Analytical Uncertainty
ISOBUTYLENE	50.00 PPM	49.33 PPM	+/- 2%
NITROGEN	Balance		



  
\_\_\_\_\_  
Approved for Release

# CERTIFICATE OF ANALYSIS

## Grade of Product: TRACEABILITY STANDARD

Part Number: X02NI99T33W0004	Reference Number: 54-402006473-1
Cylinder Number: D068357	Cylinder Volume: 32.0 CF
Laboratory: 124 - Chicago (SAP) - IL	Cylinder Pressure: 2218 PSIG
	Valve Outlet: 660
	Certification Date: Jan 26, 2021

**Expiration Date: Jan 26, 2024**

This cylinder has been analytically certified as directly traceable to NIST with a total analytical uncertainty as stated below with a confidence level of 95%, in accordance with Airgas ISO procedures. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder Below 100 psig.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Total Relative Uncertainty		
NITROGEN DIOXIDE	30.00 PPM	30.95 PPM	+/- 1% NIST Traceable		
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
GMIS	401438584104	EB0120492	48.18 PPM NITROGEN DIOXIDE/NITROGEN	+/- 1.8%	Nov 01, 2022
ANALYTICAL EQUIPMENT					
Instrument/Make/Model	Analytical Principle		Last Multipoint Calibration		
MKS FTIR NO2 017707558	FTIR		Jan 07, 2021		

Triad Data Available Upon Request

PERMANENT NOTES: OXYGEN ADDED TO MAINTAIN STABILITY



*Alan Conway*  
\_\_\_\_\_  
Approved for Release

## Using Bios Dry-Cal Flow Standard(s)

### APPLICATION INFORMATION:

Calibrator Model/S/N: TAPI T700; SN 69	NETWORK: Marathon Detroit PAMS	SITE: MTMS
Calibration Site: MTMS Site	Test Date: 3/2/2023	
Barometric Pressure (Pa, in mmHg): 743.0	Calibrated by: Jeremy Levine	
Flow Standard Model: Mesa Labs Defender 530+ M, 530+ H	Air Temp. (Ta, in deg. C): 23.1	(=deg. K): 296.3
Flow Standard Base S/N: Not Applicable	Flow Cell Model No: Defender 530+ M Defender 530+ H	
Certification Date: Not Applicable	Flow Cell S/N: 205428	205361
	Flow Cell Certification Date: 7/22/2022	7/21/2022

Check One:     X     Air Channel                      Gas Channel

(X) MFC Drive Voltage (mVDC)	Flow Meter Readings (5 sets of 10 averaged flows)					Average Flow (F1...F5) (SLPM)	STD DEV F1...F5 (in <u>SCCM</u> )	Flow Rate <u>From Previous</u> <u>Cal</u> (SLPM)	Δ% ("New Cal Flow" Vs "Prev. Cal Flow")
	F <sub>1</sub> (SLPM)	F <sub>2</sub> (SLPM)	F <sub>3</sub> (SLPM)	F <sub>4</sub> (SLPM)	F <sub>5</sub> (SLPM)				
5000	10.8520	10.8580	10.8420	10.8600	10.8530	10.853	7.0	10.832	-0.2%
4750	10.3170	10.3160	10.3150	10.3110	10.3160	10.315	2.3	10.266	-0.5%
4500	9.6906	9.6895	9.6869	9.6877	9.6923	9.689	2.2	9.708	0.2%
4250	9.1475	9.1495	9.1520	9.1448	9.1438	9.148	3.4	9.157	0.1%
4000	8.5987	8.6045	8.6008	8.6002	8.5984	8.601	2.4	8.603	0.0%
3750	8.0527	8.0573	8.0563	8.0529	8.0549	8.055	2.0	8.053	0.0%
3500	7.5167	7.5172	7.5134	7.5132	7.5105	7.514	2.8	7.507	-0.1%
3250	6.9823	6.9845	6.9790	6.9783	6.9767	6.980	3.2	6.967	-0.2%
3000	6.4503	6.4485	6.4492	6.4473	6.4441	6.448	2.4	6.430	-0.3%
2750	5.9049	5.8928	5.8966	5.9052	5.9054	5.901	5.9	5.879	-0.4%
2500	5.3137	5.3172	5.3185	5.3195	5.3172	5.317	2.2	5.334	0.3%
2250	4.7718	4.7757	4.7813	4.7790	4.7793	4.777	3.7	4.801	0.5%
2000	4.2360	4.2314	4.2315	4.2332	4.2360	4.234	2.3	4.265	0.7%
1750	3.6825	3.6817	3.6854	3.6793	3.6879	3.683	3.3	3.724	1.1%
1500	3.1393	3.1393	3.1519	3.1439	3.1461	3.144	5.3	3.189	1.4%
1250	2.6238	2.6284	2.6290	2.6273	2.6287	2.627	2.1	2.650	0.9%
1000	2.0926	2.0917	2.0912	2.0918	2.0917	2.092	0.5	2.115	1.1%
750	1.5499	1.5498	1.5498	1.5505	1.5516	1.550	0.8	1.579	1.8%
500	1.0163	1.0157	1.0146	1.0148	1.0145	1.015	0.8	1.037	2.1%
250	0.48024	0.48137	0.48059	0.48179	0.48179	0.481	0.7	0.493	2.4%
<b>SLOPE: 0.002180501</b>			<b>INTERCEPT: -0.102560589</b>			<b>CORRELATION COEFF (r):</b>		<b>0.999962608</b>	

Comments:

Technician:

Jeremy Levine  
(signature)

3/2/2023

Date



## TAPI T700 MFC Calibration Using Bios Dry-Cal Flow Standard(s)

### CALIBRATOR APPLICATION INFORMATION:

Calibrator Model/S/N:	TAPI T700; SN 69	NETWORK:	Marathon Detroit PAMS	SITE:	MTMS	
Calibration Site:	MTMS Site	Test Date:	3/1/2023			
Barometric Pressure (Pa, in mmHg):	740.0	Calibrated by:	J Levine			
Flow Standard Model:	Mesa Labs Defender 530+ L	Air Temp. (Ta, in deg. C):	22.9	(=deg. K):	296.1	
Flow Standard Base S/N:	Not Applicable	Flow Cell Model No:	530+ Low Flow			
Base Certification Date:	Not Applicable	Flow Cell S/N:	205663			
		Flow Cell Certification Date:	8/4/2022			

Check One:                           Air Channel                           **X** Gas Channel

(X) MFC Drive Voltage (mVDC)	0.0538 (5 sets of 10 averaged flows)					Average Flow (F1...F5) (SLPM)	STD DEV F1...F5 (in <u>sccm</u> )	Flow Rate <i>From Previous</i> <b>Cal</b> (SLPM)	Δ% ("New Cal Flow" Vs "Prev. Cal Flow")
	F <sub>1</sub> (SLPM)	F <sub>2</sub> (SLPM)	F <sub>3</sub> (SLPM)	F <sub>4</sub> (SLPM)	F <sub>5</sub> (SLPM)				
5000	0.05511	0.05513	0.05514	0.05507	0.05504	0.0551	0.04	0.0549	-0.3%
4750	0.05239	0.05240	0.05240	0.05241	0.05240	0.0524	0.01	0.0523	-0.2%
4500	0.04958	0.04960	0.04961	0.04963	0.04964	0.0496	0.02	0.0496	-0.1%
4250	0.04669	0.04674	0.04676	0.04680	0.04683	0.0468	0.05	0.0468	0.1%
4000	0.04415	0.04416	0.04412	0.04406	0.04405	0.0441	0.05	0.0441	0.1%
3750	0.04147	0.04148	0.04146	0.04150	0.04145	0.0415	0.02	0.0414	-0.2%
3500	0.03870	0.03873	0.03874	0.03873	0.03875	0.0387	0.02	0.0387	-0.2%
3250	0.03587	0.03589	0.03591	0.03593	0.03597	0.0359	0.04	0.0359	-0.1%
3000	0.03329	0.03327	0.03324	0.03320	0.03318	0.0332	0.05	0.0331	-0.5%
2750	0.03054	0.03055	0.03056	0.03057	0.03056	0.0306	0.01	0.0304	-0.5%
2500	0.02775	0.02777	0.02778	0.02779	0.02781	0.0278	0.02	0.0277	-0.5%
2250	0.02502	0.02498	0.02500	0.02498	0.02499	0.0250	0.02	0.0249	-0.3%
2000	0.02231	0.02232	0.02232	0.02232	0.02230	0.0223	0.01	0.0222	-0.7%
1750	0.01950	0.01951	0.01952	0.01952	0.01953	0.0195	0.01	0.0193	-0.9%
1500	0.01668	0.01667	0.01667	0.01668	0.01669	0.0167	0.01	0.0166	-0.6%
1250	0.01392	0.01393	0.01394	0.01394	0.01392	0.0139	0.01	0.0138	-0.9%
1000	0.01110	0.01106	0.01107	0.01110	0.01111	0.0111	0.02	0.0110	-1.0%
750	0.00831	0.00831	0.00832	0.00832	0.00831	0.0083	0.01	0.0082	-1.3%
500	0.00548	0.00545	0.00547	0.00546	0.00546	0.0055	0.01	0.0054	-1.9%
250	0.00261	0.00264	0.00262	0.00262	0.00262	0.0026	0.01	0.0025	-6.0%
<b>SLOPE: 0.000011</b>			<b>INTERCEPT: 0.000167747</b>			<b>CORRELATION COEFF (r): 0.999979775</b>			

Comments: \_\_\_\_\_

Technician: Jeremy Levine

(signature)

3/1/23

Date

*C: State Monitor Map*

# Michigan Air Monitor Network

