



- KEYNOTES:**
- 1 FULLY ADHERED SINGLE-PLY ROOFING MEMBRANE ON TAPERED INSULATION ON 1/2" MINIMUM ROCK INSULATION OVER REINFORCED PRECAST CONCRETE SLAB
 - 2 PREFINISHED METAL SCUPPER AND DOWN SPOUT
 - 3A PRECAST CONCRETE WALL PANEL SYSTEM - 12" PRECAST WALL PANEL WITH 1/2" THICK EMBEDDED BRICK - REFER TO STRUCTURE DWGS. FOR REINFORCING
 - 3B PRECAST CONCRETE WALL PANEL SYSTEM - 12" PRECAST WALL - REFER TO STRUCTURE DWGS. FOR REINFORCING
 - 3C NOT USED
 - 3D REINFORCED PRECAST CONCRETE TEE WITH CONCRETE TOPPING
 - 4A PREFINISHED METAL PANEL SYSTEM, PREFINISHED GALVANIZED STEEL, 1 1/2" VERTICAL METAL PANEL WITH CONCEALED FASTENERS ON 3/4" X 1/4" CHANNELS ON WEATHER RESISTANCE BARRIER ON PRECAST CONCRETE WALL PANEL
 - 4B PREFINISHED METAL PANEL SYSTEM BY STOREFRONT MFR.
 - 5 PREFINISHED ALUMINUM CURTAIN WALL SYSTEM - REFER TO ELEVATIONS FOR TYPES
 - 6A PREFINISHED ALUMINUM STOREFRONT SYSTEM
 - 6B NOTE: PROVIDE TEMPERED GLASS WHERE REQUIRED BY CODE.
 - 6C PREFINISHED ALUMINUM FRAME EXTENSION PROVIDED BY WWS MANUFACTURER (FINISH TO MATCH ADJACENT WWS) W/ CONCEALED GLASS ATTACHMENT
 - 7 REFER TO STRUCTURAL DOCUMENTS FOR COLUMNAL BEAMS, OTHER SHAPES, FLOOR SLABS AND SPECIFIC REINFORCING REQUIREMENTS.
 - 8A MISCELLANEOUS STEEL ITEMS
 - 8B REFER TO STRUCTURAL DOCUMENTS FOR CONCRETE WALLS, FOUNDATIONS, SIZES AND DETAILS.
 - 9 REINFORCED CONCRETE SLAB ON VIPOB BARRIER OVER COMPACTED GRANULAR FILL - REFER TO STRUCTURAL DOCUMENTS FOR REINFORCING.
 - 10A EXTERIOR REINFORCED CONCRETE SUPPORTED SLAB ON GALVANIZED METAL DECK ON VOID SPACE - REFER TO STRUCTURAL DOCUMENTS FOR REINFORCING.
 - 10B REINFORCED CONCRETE SLAB ON COMPACTED SAND FILL - REFER TO ARCH. SITE PLAN AND CIVIL DOCUMENTS FOR FURTHER DETAIL AND FINISH TYPES.
 - 10C NOT USED
 - 11 EMBEDDED STAINLESS STEEL FLASHING WITH DRIP - EXTEND 1/2" BEYOND FACE OF MASONRY.
 - 12 DAMPROOFING OVER CONCRETE FOUNDATION
 - 13 1/2" PREMOULDED JOINT FILLER AND SEALANT.
 - 14 CONTINUOUS SEALANT AND BACKER ROD - 3/8" U.N.O.
 - 15 CMU WITH HORIZONTAL JOINT REINFORCEMENT @ 16" O.C. REFER TO FLOOR PLANS FOR WALL TYPES
 - 16A NOT USED
 - 16B NOT USED
 - 16C STAINLESS STEEL CABLE GUARDRAIL SYSTEM
 - 17 DOOR AND FRAME AS SCHEDULED
 - 18 3" THICK X 2 1/2" WIDE, RIGID PERIMETER INSULATION (U.N.O.) EXTEND HORIZONTALLY MIN. 2 1/2" & VERTICALLY MIN. 2 1/2" (U.N.O.)
 - 19 ARCHITECTURAL LOUVER - REFER TO MECH. DWGS AND SPECIFICATION
 - 20 PAINTED GALVANIZED WIRE MESH SCREEN - REFER TO SPECIFICATION
 - 21 PREFINISHED ARCHITECTURAL OVERHEAD COOLING DOOR SYSTEM.

NOTE:
 1. ALL EXTERIOR STEEL TO BE GALVANIZED - TOP (U.N.O.)
 2. CURTAIN WALL SYSTEM BASES OF DESIGN PROFILE - 80/10 LINE 2 1/2" AND DEPTH 1" AT RETAIL SPACE AND 7" AT STAIR ELEVATOR TOWER (UNLESS NOTED OTHERWISE)

GRAPHIC LEGEND

- BRICK VENEER TYPE 1
- BRICK VENEER TYPE 2
- BRICK VENEER TYPE 3
- STONE VENEER
- METAL PANEL INFILL (HORIZONTAL)
- METAL PANEL INFILL (VERTICAL)

NOTE: ALL CURTAIN WALL COLOR TO BE CW1 (U.N.O.) ALL GLAZING TO BE GL1 (U.N.O.)

- OPENING CONDITION #1 - CLEAR OPENING
- OPENING CONDITION #2 - 4"x4" WIRE WELDED MESH @ REAR OF OPENING
- OPENING CONDITION #3 - 4"x4" WIRE WELDED MESH BEHIND ALUMINUM FRAME
- OPENING CONDITION #4 - VEHICULAR CABLE BARRIER BEHIND ALUMINUM FRAME

Issued for _____

- 11.22.2021 HDC Comments
- 11.01.2021 City Comments
- 10.01.2021 Addendum #1
- 09.16.2021 Bids and Permit
- 07.29.2021 50% Construction Documents
- 06.17.2021 Design Development R1
- 03.18.2021 Design Development

Drawn Preliminary
 JK Construction
 Checked Record
 JK Approved **Do not scale**
 JLS Use figured dimensions only
 Bidpak Number _____

Job Number
2020009
 Title
BUILDING ELEVATIONS