

From: Raid (Ray) Jamil <rjamil@hamilton-anderson.com>
Sent: Thursday, December 8, 2022 8:03 AM
To: Jennifer Ross <rossj@detroitmi.gov>; Historic District Commission (Staff) <hdc@detroitmi.gov>
Cc: Rainy Hamilton <rhamilton@Hamilton-Anderson.com>; Ashley Packwood <apackwood@clc.build>; Cory Wingelaar <CWingelaar@Hamilton-Anderson.com>
Subject: [EXTERNAL] RE: 7441 Second Avenue - Re-submission for re-roofing and window replacement

This Message Is From an External Sender

ATTENTION: This email was sent from an external source. Please be extra cautious when opening attachments or clicking links.

Hi Jennifer,

The corresponding dimensions for the new windows on the first and second floors are 1 ¾" . Please refer to attached file.

For the answer of the second question, refer to table below:

Note that the windows dividers for the existing windows are muntins. While the dividers for the new windows are simulated.

Let me know if you have any other note.

Thank you,

Height of the pane of glass at the existing windows at the 1ST floor	Height of the pane of glass at the new windows at the 1ST floor	Height of the pane of glass at the existing windows at the 2ND floor	Height of the pane of glass at the new windows at the 2ND floor
four individual panes. 1'-10" height each	Two individual panes. 3'-7 1/2" height each	four individual panes. 1'-4" height each	Two individual panes. 2'-7" height each

Raid [Ray] Jamil, RA,OAA,NCARB, LEED Assoc
Architect
313 887 6316 d
313 964 0270 p