

4.0 ROOFING SYSTEM

4.1 Limitations

- △ Accessories Partly Concealed.
- △ Chimney(s)/Vent(s)/Cap(s) partly concealed.
- △ Flashing(s) partly concealed.
- △ Height
- △ Height
- △ Height
- △ Rainy/Wet
- △ Steep Slope
- △ Tree Debris/Limbs
- △ Unknown Age
- △ Unknown Age
- △ Vegetation

4.2 Roofing Inspection Method

- ⊙ Inspected from roof edge.

4.2.1 General Information:

Roof inspections are limited to visible and accessible areas.

4.3 Sloped Surface(s)

- ⊙ Typical Life Cycle: 20-25 Years
- ⊙ Asphalt/Fiberglass
- ⊙ Beginning of Life Cycle

4.3.1 **Approx. Age: 1980**

The wood shake roof on the home needs immediate replacement or extensive repairs.

Damaged/Rotted shakes noted throughout the roof. Consult a wood shake specialist for repairs.







4.3.2 Approx. Age: 2015

