

May 12, 2016

ATC Associates
46555 Humboldt Dr.
Suite 100
Novi, MI 48377

Subject: Western Int. HS - 1500 Scotten
188BS16170

Dear Mr. Smith :

Thank you for making Brighton Analytical, L.L.C. your laboratory of choice. Attached are the results for the samples submitted on 05/02/2016 for the above mentioned project. NELAP/TNI Accredited Analysis and MDEQ Drinking Water Certified Analysis will be identified in their respective reporting formats. Hard copies can be supplied at your request for a fee of \$20.00 per copy.

The invoice for this project will be emailed separately. If you have any questions concerning the data or invoice, please don't hesitate to contact our office. We welcome your comments and suggestions to improve our quality systems. Please reference Brighton Analytical, L.L.C. Project ID 38838 when calling or emailing. We thank you for this opportunity to partner with you on this project and hope to work with you again in the future.

Sincerely,
Brighton Analytical, L.L.C.



Brighton Analytical, L.L.C.
Email: ba@brighton-spcglobal.net
2105 Pless Drive
Brighton, MI 48114
Phone: 810-229-7575
Fax: 810-229-8650

BA PROJECT #:
38838

Analysis Requested/Method

PAGE 1 of 1
COMPANY/MAILING ADDRESS:

PROJECT NAME:

Western Int. HS-1500 Scatter

PROJECT #:

1887816170

PO #: (PLEASE NOTE IF DIFFERENT BILLING ADDRESS)

ABBREVIATIONS
FOR MATRIX
S = Solid
L = Liquid
DW = Drinking H₂O
O = Oil
P = Wipe
A = Air (Tear Bag)
F = Filter
T = Tube
M = Misc.

Sample collected by:

Daniel L. Hether

REQUESTED TURNAROUND: (circle one)

Rush: 1-3 business days (verify with lab & specify date needed)

1 Day = 2.5X Cost 2 Day = 2X Cost 3 Day = 1.5X Cost

Standard: 5 business days

If RUSH, approved by:

Sample Coll.

Brighton ID #

Sample Description

Date Time

VOA'S (PRES) Y N N/A

HDPE UNPRESERVED

HDPE HNO₃

HDPE H₂SO₄

HDPE NAOH

AMBER PRESERVED?

GLASS, NO PRESERVATIVE

STERILIZED BACTERIA

MEOH Preserved Y N

Container Type & Quantity

Sample Matrix

LEAD - Primary (P)
Copper - Primary (P)
LEAD - FLUSH (F) - Hold
Copper FLUSH (F) - Hold

Temperature of samples °C: *20/16.5*
pH's verified in login? yes ☒ no ☐
Headspace/bubbles in VOA's? yes ☐ no ☐ n/a ☒
Sample containers and COC match? yes ☒ no ☐

BILLING ADDRESS (IF REQUIRED):

Same as MCL

Drinking H₂O:

Fax to LCHD? yes ☐ no ☒

Chlorinated Water Supply? yes ☒ no ☐

AMT.: *100*

MCL Failure: yes ☐ no ☐

Client Notified (date/time/initials):

Special Instructions: *If Lead or Copper Phase Detection Limits - Analyze FLUSH Sample*

Please fill out the Chain of Custody completely and review. Incorrect or incomplete information will result in a "hold" on all analyses.

Trans. #	RELINQUISHED BY:	RECEIVED BY:	DATE:	TIME:	Trans. #	RELINQUISHED BY:	RECEIVED BY:	DATE:	TIME:
1	<i>Daniel L. Hether</i>	<i>Daniel L. Hether</i>	<i>5/24/16</i>	<i>1045</i>	3				
2	<i>Daniel L. Hether</i>	<i>Daniel L. Hether</i>	<i>5/24/16</i>	<i>1130</i>	4				



Brighton Analytical LLC
2105 Pless Drive
Brighton, Michigan 48114
Phone: (810)229-7575 (810)229-8650
e-mail: bai-brighton@sbcglobal.net
MDNRE Certified #9404
NELAC Accredited #176507

Sample Date/Time: 4/30/2016 09:00
Submit Date/Time: 5/2/2016 11:30
Report Date: 5/12/2016

ATC Associates
46555 Humboldt Dr.
Suite 100
Novi, MI 48377

BA Project # **38838**
BA Sample ID **CD01883**

Project Name: **Western Int. HS - 1500 Scotten**
Project Number: **188BS16170**
Sample ID: **1-F-P-WHS-Teacher's Lounge**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Copper (Drinking Water)	170	ug/L	20	1300	EPA 200.8 rev5.4	11:28	05/11/2016
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:28	05/11/2016

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

5/12/16



Brighton Analytical LLC
2105 Pless Drive
Brighton, Michigan 48114
Phone: (810)229-7575 (810)229-8650
e-mail: bai-brighton@sbcglobal.net
MDNRE Certified #9404
NELAC Accredited #176507

Sample Date/Time: 4/30/2016 09:06
Submit Date/Time: 5/2/2016 11:30
Report Date: 5/12/2016

ATC Associates
46555 Humboldt Dr.
Suite 100
Novi, MI 48377

BA Project # **38838**
BA Sample ID **CD01885**

Project Name: **Western Int. HS - 1500 Scotten**
Project Number: **188BS16170**
Sample ID: **2-F-P-WHS-Kitchen**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Copper (Drinking Water)	250	ug/L	20	1300	EPA 200.8 rev5.4	11:46	05/11/2016
Total Lead (Drinking Water)	5	ug/L	1	15	EPA 200.8 rev5.4	11:46	05/11/2016

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date

5/12/16



Brighton Analytical LLC
2105 Pless Drive
Brighton, Michigan 48114
Phone: (810)229-7575 (810)229-8650
e-mail: bai-brighton@sbcglobal.net
MDNRE Certified #9404
NELAC Accredited #176507

Sample Date/Time: 4/30/2016 09:09
Submit Date/Time: 5/2/2016 11:30
Report Date: 5/12/2016

ATC Associates
46555 Humboldt Dr.
Suite 100
Novi, MI 48377

BA Project # **38838**
BA Sample ID **CD01887**

Project Name: **Western Int. HS - 1500 Scotten**
Project Number: **188BS16170**
Sample ID: **3-DWC-P-WHS-Cafeteria**

Analyte Name	Result	Units	RL	MCL	Method Reference	Analysis Time	Analysis Date
Drinking Water Metal Analysis							
Total Copper (Drinking Water)	90	ug/L	20	1300	EPA 200.8 rev5.4	11:51	05/11/2016
Total Lead (Drinking Water)	Not detected	ug/L	1	15	EPA 200.8 rev5.4	11:51	05/11/2016

RL=Reported detection limit for analytical method requested. Some compounds require special analytical methods to achieve MDNR designated target detection limits (TDL).

MCL = Maximum contaminant Levels.

Analysis not specifically identified as drinking water are for non-regulatory compliance purposes.

Released by

Date


5/12/16



BRIGHTON ANALYTICAL, LLC

QUALITY ASSURANCE/QUALITY
CONTROL

ICP-MS

METHOD 200.8/6020

REPRESENTATIVE BATCH PRECISION AND ACCURACY QUALITY CONTROL SUMMARY

Analysis Date: 5/11/2016

Standard ID: 050416 H2O

Batch: 5/9/2016 W3

Matrix Spike Lab ID: CD01973

Matrix: Total

Analyst: LT

Metals	Matrix Spike - Precision *			Matrix Spike - Accuracy**				Miscellaneous***		
	Matrix Spike (ug/kg)	Matrix Spike Dup (ug/kg)	RPD (%)	Spk Conc (ug/kg)	MS Recovery (%)	MSD Recovery (%)	Sample Conc (ug/kg)	Method Blk (ug/kg)	LCS-Method STD (%)	Ind. Std. (%)
Chromium	953	1019	6.7	1000	95.3	101.9	0	<5	102.9	99.9
Copper	957	1028	7.2	1000	95.2	102.3	5	<4	105.2	102.9
Arsenic	960	1032	7.2	1000	95.3	102.5	7	<1	102	97.9
Lead	962	1007	4.6	1000	96.2	100.7	0	<1	101.8	95.3

* Matrix spike precision range +/- 20% RPD

** Matrix spike accuracy range +/- 20% recovery

*** LCS accuracy range +/- 15% recovery / Ind std accuracy range +/- 10% recovery

Comments: _____