## SECTION 05400 – PROVISIONAL

## COLD-FORMED FRAMING

***Provisional Specification Summary:***
*1.1. – Replace this section with a new section as shown below*
*1.3.04 – Delete this subsection*
*3.2.01 – Delete this subsection*
*3.2.03 – Replace subsection and heading with new as shown below*

***(Update text as shown.)***

1.1 SCOPE. This section includes axially loaded steel 0.097 studs, slotted channels, trusses and connections, usually of 0.033 inch (0.8 mm) to 0.097 inch (2.5 mm) metal thickness. Section also includes bracing, fasteners and accessories.

3.2.03 Trusses Install level, straight & plumb, complete with bracing and reinforcing as indicated on drawings. Provide not less than 1 ½ inch (3.8 cm) end bearing. Trusses shall be located directly over bearing walls.

End of Provisional Section

THIS PAGE LEFT INTENTIONALLY BLANK