PREPARED BY: A. DYE

STAFF REPORT: 10-14-2020 MEETING APPLICATION NUMBER: 20-6884 ADDRESS: 1035 CLARK HISTORIC DISTRICT: HUBBARD FARMS APPLICANT: LOGESH RAJENDRAN, DMC CONSULTANTS; CITY OF DETROIT BRIDGING NEIGHBORHOODS PROGRAM PROPERTY OWNER: LEOPOLDO HERNANDEZ DATE OF PROVISIONALLY COMPLETE APPLICATION: 10/14/2020 DATE OF STAFF SITE VISIT: 10/02/2020

#### SCOPE: REPLACE EXISTING WOOD WINDOWS WITH NEW WOOD WINDOWS

#### **EXISTING CONDITIONS**


The 2-1/2 story Queen Anne structure at 1035 Clark was built in 1913. Sited high on the property, steps lead up to the covered entrance which is supported by iron columns. Vinyl siding covers the majority of the house and its installation covered the window casings and aluminum trim capped the wood brick mould. A two-story bay window culminating with a large gable dominates the front elevation. A pediment on the covered front entry and a pedimented dormer above, along with a steeply pitched roof, creates a strongly angled front facade.

Historic exterior materials which remain exposed include the brick chimney on the south elevation and the stone cladding on the front entrance wall. Wood windows are present within most of the existing window openings; a leaded glass transom remains in situ on the south elevation.


A single story addition was constructed at the rear of the house between 1921 and 1950 (according to the Sanborn maps). The exterior walls of the addition are faced with a mottled yellowish-orange brick. Minimal detailing to the exterior walls a low pitch hip roof allows the original house to retain dominance on the site. The windows within the addition are 1-over-1 double hung, matching the predominate window operation on the main house. The contractor states in the application that the three double-hung windows within the rear addition, as well as one additional window on the south elevation (identified as B5) of the house, are wood framed, vinyl-clad windows.



Above photo: HDC staff, October 2, 2020. Photo on right: Applicant provided, date not known.




Sanborn Map Company, Vol. 1, 1921, section 102



Sanborn Map Company, Vol. 1, 1921 - Oct 1950, Sec. 102

The house is located within the Bridging Neighborhoods Program. Per the City of Detroit's website: The Bridging Neighborhoods I-75 Environmental Mitigation Program offers home mitigations to address noise and air quality impacts from increased truck traffic related to the Gordie Howe International Bridge Project. Eligible homes may receive some or all of the following mitigations: updated windows, updated HVAC systems, air filters, and insulation.

- Must live in either the YELLOW or GREEN zone on the map AND
- Must own a property that is within 300 feet of the planned I-75 Service Drive AND
- Must not have been acquired by the Michigan Department of Transportation to facilitate construction of the bridge



#### PROPOSAL

The applicant proposes to remove all of the existing windows within the house and install replacement windows as allowed by the Bridging Neighborhoods 1-75 Mitigation Program. Specifically, the applicant is seeking the Commission's approval to remove all existing window sash and window jambs and replace with new wood, aluminum-clad window sash as per the submitted window quote. The applicant confirmed with HDC staff the existing casings, inner stop, and brick mould will be retained/will remain in their current condition.

The dominant window style is double-hung, with one-over-one wood sash. Exceptions to this condition include:

- First floor, front elevation, center bay fixed wood frame window with transom above.
- First floor, side elevation, fixed wood frame window and leaded glass transom above.
- First floor, sides and rear, four replacement wood double-hung (one-over-one) vinyl clad windows (three on addition, one on south elevation of house).
- Second floor, rear elevation, vinyl frame sliding window.
- Third floor, rear elevation, two square casements (each with a two-over-two muntin pattern) and wood mullion

According to the applicant's window replacement order, the leaded glass transom would be replaced with a clear glass transom that would be factory mulled to the new fixed window. A fixed (or casement) clear glass window will replace the existing slider. The square casements will be replaced with square casements but would have between-the-glass grids.

#### STAFF OBSERVATIONS AND RESEARCH

- The Hubbard Farms Historic District was established in 1992.
- According to DPI, the HDC issued a COA for this property in December 1993. The scope notes within the electronic file state: "install vinyl siding, replace windows per guidelines".
- It is staff's understanding the vinyl siding installation caused the wood brick mould to be covered in order to keep water away from the house. If the brick mould had been left exposed, water would run down the wood, travel behind the siding, and become trapped between the siding and the house.
- A window opening on the rear (west) elevation appears to have been reduced in size to accommodate a sliding window. The original window opening is evident as the vinyl siding does not extend to the sliding window frame.

#### **ISSUES**

- The window replacement includes not just the operable sash but also the window jambs. The applicant confirmed with HDC staff the casings, inner stop, and brick mould will be retained and the windows will remain covered with aluminum trim.
- The applicant has not identified the exterior aluminum-cladding color.
- The proposed windows only offer between-the-glass muntins.
- The window order proposes to replace ALL of the windows in the house; the leaded glass transom will be removed and replaced with a clear glass transom.
- The applicant proposes to install Weather Shield Windows, Weather Shield series. These are wood-framed units with exterior aluminum cladding. The comparison of the existing wood frames against the Weather Shield window frames is below.

| Existing Frames        |        | Proposed Frames        |         | Percentage Increase |
|------------------------|--------|------------------------|---------|---------------------|
| Width of frame         | 2"     | Width of frame         | 3-3/16" | 62%                 |
| Depth of frame         | 1-3/8" | Depth of frame         | 4-9/16" | 200%                |
| Height of meeting rail | 1-3/8" | Height of meeting rail | 2-7/8"  | 100%                |
| Depth of meeting rail  | 1-3/8" | Depth of meeting rail  | 3-3/16" | 133%                |

• The Weather Shield, wood aluminum-clad windows have substantially thicker window frames. The dimensional increase is too large, and the loss of the leaded glass transom and between-the-glass muntins are not compatible with the scale and architectural features of the existing windows and house. Therefore, it is staff's opinion the proposed windows do not meet the Secretary of the Interior Standards.

#### RECOMMENDATION

Staff recommends the Commission consider issuing a NOTICE TO PROCEED for the window replacement at 1041 Clark Avenue. As this property falls within the service area of the Bridging Neighborhoods I-75 Environmental Mitigation Program, the Notice to Proceed may fall under the following Condition:

2) The resource is a deterrent to a major improvement program that will be of substantial benefit to the community. Substantial benefit shall be found only if the applicant proposing the work has obtained all

necessary planning and zoning approvals, financing, and environmental clearances, and the improvement program is otherwise feasible;

If a Notice to Proceed is issued, staff recommends the Commission include the following conditions:

- The existing windows will remain in place until the replacement windows are approved by Commission staff.
- The new window frame dimensions shall not increase more than <sup>1</sup>/<sub>4</sub>-inch (from the existing frame dimensions).
- The operation and glass within each new window unit will match the existing window.
- The leaded glass transom window will remain in place and be repaired as needed.
- Existing wood mullions, if present, will remain in place. New, single window units will be inserted into existing window openings.
- The casement windows will have a simulated divided light muntins pattern.
- The new windows will be solid wood (exterior to be painted) **or** solid wood, aluminum-clad units. The exterior frame color will be submitted for review.
- The existing exterior wood brick mould will be retained and will remain covered with aluminum.

If any of the above conditions not be met, HDC staff will require the applicant to submit a revised proposal for the Commission's review at an upcoming meeting.







THIS IS A 3-PAGE FORM - ALL INFORMATION IS REQUIRED FOR PROJECT REVIEW

# HISTORIC DISTRICT COMMISSION PROJECT REVIEW REQUEST

City of Detroit - Planning & Development Department 2 Woodward Avenue, Suite 808 Detroit, Michigan 48226

Date: 8/20/2020

| PROPERTY INFORMATION   |                                   |  |  |  |  |
|--|-----------------------------------|--|--|--|--|
| ADDRESS: 1035 Clark Street AKA:  |                                   |  |  |  |  |
| HISTORIC DISTRICT: Hubbard Farms  SCOPE OF WORK:  Windows/ Check ALL that apply)  New Construction Demolition Additio  | Tree/Park Rehab                   |  |  |  |  |
| APPLICANT IDENTIFICATION   |                                   |  |  |  |  |
| Property Owner/       Contractor       Tenant or Business Oct         NAME: Logesh Rajendran       COMPANY NAME:   |                                   |  |  |  |  |
| ADDRESS: 13500 Foley CITY: Detroit   | _ STATE:_MI ZIP: <sup>48209</sup> |  |  |  |  |
| PHONE: 3134911815 MOBILE: EMAIL: logeshr@dmcconsultantsusa.com   |                                   |  |  |  |  |
| <b>PROJECT REVIEW REQUEST CHECKLIST</b><br>Please attach the following documentation to your request:<br><b>*PLEASE KEEP FILE SIZE OF ENTIRE SUBMISSION UNDER 30MB*</b>      | NOTE.                             |  |  |  |  |
| x Completed Building Permit Application (highlighted portions only)  |                                   |  |  |  |  |
| ePLANS Permit Number (only applicable if you've already applied<br>for permits through ePLANS) additional documentation may<br>be required.<br>See www.detroitmi.gov/hdc for |                                   |  |  |  |  |
| x       Photographs of ALL sides of existing building or site       I scope-specific requirements.   |                                   |  |  |  |  |
| <b>Detailed photographs</b> of location of proposed work (photographs to show existing condition(s), design, color, & mater  | rial)                             |  |  |  |  |
| <b>X</b> Description of existing conditions (including materials and de  | esign)                            |  |  |  |  |
| <b>Description of project</b> (if replacing any existing material(s), in replacementrather than repairof existing and/or construction  |                                   |  |  |  |  |

Brochure/cut sheets for proposed replacement material(s) and/or product(s), as applicable

Detailed scope of work (formatted as bulleted list)

Upon receipt of this documentation, staff will review and inform you of the next steps toward obtaining your building permit from the Buildings, Safety Engineering and Environmental Department (BSEED) to perform the work.

# SUBMIT COMPLETED REQUESTS TO HDC@DETROITMI.GOV

# 1035 Clark

City of Detroit Bridging Neighborhoods I-75 Environmental Mitigation Program



# **Description of Project**

The Bridging Neighborhoods Program was created by City Council Resolution and approved by the Mayor on July 26, 2017.

The home for which this application was created falls within the service area of the I-75 Environmental Mitigation Program which, per Exhibit A Item H. of the resolution is required to provide a "retrofit package designed to protects occupants of the Retrofit-Eligible Home from air pollution and noise pollution.... Retrofit packages may include new windows; air filters; insulation; and/or heating, ventilation, and air conditioning systems."

Because of the requirement to provide new windows, we seek permission to replace the existing windows.

# Description of Existing Conditions


The property at 1035 Clark street has existing single pane, double hung wood windows.

As you review the provided images, you will see that these windows are in various states of repair.

The windows all have exterior white paint.

Window C1 and C2 are casement windows Window C3- Vinyl window Window C4, B4, B5 and D4 are wood windows with vinyl cladding outside.


NOT TO SCALE




EXISTING SASH DETAILS 1035 CLARK and 1041 CLARK

NOT TO SCALE

EXISTING MEETING RAIL




1035 CLARK AND 1041 CLARK



EXISTING SILL AND JAMB


# CASEMENT WINDOW - 1085 CLARK





1035 CLARK

EXISTING BRICK MOLD - COVERED WITH ALUMINON TRIM








# Scope of Work

 Replacing existing wood windows with new STC 27 wood windows. Interior casings and stops will be retained.
 Exterior brick mold is covered with white aluminum trim outside (refer to the pictures attached).

# Brochure/Cut Sheet

# Weather Shield®


# Weather Shield Series™




#### WEATHER SHIELD DOUBLE HUNG WINDOW (610) Horizontal Section

# **Double Hung Windows**

## **CROSS SECTION DETAILS**




WEATHER SHIELD DOUBLE HUNG WINDOW Horizontal Stack Section - Transom Stack over DH



#### WEATHER SHIELD DOUBLE HUNG WINDOW Vertical Mull Section - DH / DH

Note: All dimensions are approximate. Weather Shield reserves the right to change specifications without notice.



#### www.weathershield.com

REV 7/17



## EXTERIOR COLOR OPTIONS

To help you get the exact look you desire, we offer an ever-expanding palette of durable and distinct exterior color options rated to the highest industry standards (AAMA 2605) for color retention. Our Premium windows and doors are available in 12 standard and 45 designer colors, 8 anodized and 4 radiant metallic colors, with unlimited custom color match aluminum finishes.



#### Designer Exterior Colors (AAMA 2605 premium paint)







#### Textured Exterior Aluminum Finishes



Finishes and colors shown may not be actual representations. Please visit an authorized Weather Shield dealer for color samples.



## INTERIOR WOOD OPTIONS

Every home is different. So we give you choices to add your own special touch. Choose the wood grain and color that complement your design. Then add warmth and beauty with our factory finishes. Whether subtle or stunning, you'll find options to make a lasting impression.

#### **Rich Wood Interiors**

With eight wood species to choose from, there's sure to be one perfect for your home. For a truly unique look, other wood species are available upon request.





#### **Durable Factory Finishes**

Save time and money with our factory finishing. The wood is stained and sealed on all surfaces to repel moisture and includes two Clear Satin top coats for durability and easy cleaning.



#### **Designer Stains**

Explore our new furniture-grade stain offering created in partnership with leading paint and coatings manufacturer Sherwin-Williams®. These new stains provide clean, vivid colors with high pigmentation for excellent clarity and uniformity.

# SHERWIN-WILLIAMS.

PROUDLY FINISHED WITH

#### 7 Step Process

Our intensive seven step process creates a long-lasting premium finish that will protect and enhance the beauty of your windows and doors for years to come.

#### FINE SANDING WASH COAT STAIN COAT SEALER COAT BUTFING TONER COAT. CLEAR COAT COMPLETED FINISH Prepares wood to A toned wood Primary color Builds a smooth 5.rfsces are buffed This step is used to A specially formulated 2K Polyurethane accept coatings. conditioner that cost, designed to surface that looks to create an ultraeven out the color to pocat dasigned to protect from UV and fills wood pores. highlight the natural down the color and amonth surface. and add depth and scratching. beauty of the wood. provides chemical and creates an richness to the final even finish. andmosture co icr. resistance.

7 STEPS TO CREATE A FURNITURE GRADE STAIN

Finishes and colors shown may not be actual representations. Please visit an authorized Weather Shield dealer for color samples. All finishes not available on all wood spacies. Please visit an authorized Weather Shield dealer for catalis.

#### 30

31

#### DOUBLE HUNG WINDOWS

Glass: Insulated Low-E with Argon

## ARCHITECTURALLY INSPIRED, TECHNOLOGICALLY ADVANCED

Our double hung windows represent a one-of-a-kind approach to a popular choice in home design. With the versatility to open from the top or bottom, a breath of fresh air is never out of reach. From robust ventilation to energy efficiency and ease of use, double hung windows are a timeless classic.



Natural Finish A wood jambliner covers all mechanical balance systems to create a tailored aesthetic

Tilt and Release With concealed tilt release latches. nothing comes between you and the view. Recessed into the lock rail, this design element leaves the sash clear of all visible latch hardware.



Single Handed Ease The single dual action lock allows the sash to be unlocked and tilted easily with one hand - so you can save your energy for the things that really matter.

#### High Quality Exteriors

Our aluminum exterior-ciad wood products feature commercial-grade premium AAMA 2605 paint that resists fading and chalking. Extruded aluminum resists dents, dings and scratches and is backed by Weather Shield's 20-year limited warranty.

The 3-1/2" bottom rail creates clean lines and ideal architectural proportions.

#### The Beauty is in the Details

The rigid integral nailing fin makes installation simple and provides more durability than flimsy snap-in or fold-out fins found with other windows.

Butt jointed dadding accurately mimics traditional wood windows for a familiar aesthetic.






## OUTSTANDING PERFORMANCE, EXCEPTIONAL EFFICIENCY

Selecting the right windows is crucial in determining the style and elegance of your home. We offer only top-of-the-line design and construction, so you can choose among the industry's most innovative options. State-of-the-art windows like these are an investment that pays for itself in a lifetime of reduced costs.

#### The Perfect Grille

Personalize your home with windows featuring a selection of bar widths and profiles, as well as traditional grille patterns and custom designs. For even greater creativity and design flexibility, most grilles can be manufactured from Weather Shield's custom wood interiors collection.



RECTANGULAR






SINGLE HORZONTAL BAR

PRAIDE



PRAFIE W/ VERTICAL BAR






Innovative Design; Classic Appeal The best of modern energy efficiency meets old-world charm in Simulated Divided Lite (SDL) grilles. While mimicking the look of classic single-pane windows, SDL grilles offer exterior and interior grille bars either with or without an aluminum spacer bar --- translating to powerful insulation and innovation.

Framed With You in Mind

Square Interior Wood Profile

Featuring a unique perimeter grille frame design that rests on the inside of the unit. Weather Shield windows employ a concealed pin system to snap the perimeter grille frame securely into place. These grilles can be easily removed in order to clean the entire interior glass surface.





Grilles Between the Glass Airspace Grilles seal aluminum grille bars in either a sculpted or flat design between two panes of glass. Resulting in a classic

aesthetic that is easy to clean and maintain.





5.8" FLAT

11/16" SCULPTURED

COTTAGE

ORE.

SMULATED DOUBLE HUNG



## REFLECTIONS OF QUALITY

From specialty glass to high-end glazing, our windows are truly a cut above the rest. Add color and texture options to the glass in your home while enjoying the energy efficiency and quality for which we're known best.

#### Gold Standard

Weather Shield Premium Series products are certified and labeled according to the highest standards, set by the Window and Door Manufacturers Association (WDMAI/National Fenestration Ratings Council (NFRC) Certification Program. Al WDMA/NFRC certified products must pass performance tests conducted by an independent lab for resistance to air leakage, water penetration and wind pressures.

#### Specialty Glass Options

Add color or texture - or privacy and modesty - to your palette of design options. Special finishes and tint can give a project distinction. Specialty glass includes bronze, gray, rain and obscure.



#### High Quality Glaze

Maximize your windows' energy efficiency with the exclusive Zo-e-shield's glazing system. With powerful layers of Low-E coating, optional EasyCare® surface costing, inert gas-filled insulating airspace, and Real Warm-Edge® spacers, our glazing options represent the ultimate in energy efficiency for any climate.

#### **Glazing Options**



Insulated Low-E

All Climate · Minimizes the sun's heat

and damaging UV rays in warmer months. · Reflects the sun's heat back into room during cooler months

insulating value. · Excellent protection against damaging UV rays.

Zo-e-shield 5

Ultimate Solar Control

· Strong resistance to the

san's glating heat.

· Excellent

· Maintains great clarity

#### Zo-e-shield Zo-e-shield 5 Plus

Laminated Interior

· Best resistance available to the sun's heat

Zo-e-shield

· Great insulating value

blocks the sun's heat

in warmer months

all climate regions

· Controls glare and

· Excellent for use in

Triple Glazed with

5 Coats of Low-E

- Minimizes glare and
- visible light transmittance Superior sound control
- and UV protection

#### Energy Star

As a proud ENERGY STAR® partner, Weather Shield products are rated, certified and labeled for U-Value and Solar Heat Gain by the National Fenestration Rating Council (NFRC). Many of Weather Shield® windows not only meet, but exceed ENERGY STAR® standards for energy efficient windows and doors. Using ENERGY STAR® windows can also help you save money through various tax rebates and incentives.





The ENERGY STAR® criteria for residential windows and doors are tailored to four Climate Zones. A product's energy efficiency for a given climate is based on its impact on heat gain and loss in cold weather and heat gain in warm weather. Check to see what ENERGY STAR® climate zone you live in utilizing the climate map above.

# Zo-e-shield

Plus Room Side Low-E

· Compination of two

energy off clency

· Significantly incroved

· Complies with northern

interior LoE i89 coating

Energy Star guidelinas with

los-e cortings





### SCREEN AND TRIM OPTIONS

Weather Shield's high-visibility screen options maximize your view and allow more light to flow in. Then add unparalleled design flexibility and customization with our wood interior and aluminum exterior trim options. Available for curved and angle-shaped windows and doors, adding distinctive architectural detail.

#### Screen Options

Screens allow you to enjoy fresh air flow throughout your home all while keeping out pesky insects. Our High-Visibility, No See-um screen doth utilizes a much finer mesh that offers more air flow along with better optical clarity. Also available in aluminum, non-glare mesh.

#### Retractable and Wood Screen

Our retractable screen offers unmatched operation with a fully concealed screen channel that maximizes your viewing area. Engineered brake system allows for hands free operation and smooth screen retraction with fully concealed screen components creating a tailored upscale aesthetic.

Hinged from the side, and easily removed for repairs or maintenance, our wood hinged screen option welcomes the natural wood character into your home.

# NO SEE UN WESH



AUMINUMINON-GLARE MESH

#### Exterior Trim Options

Our exterior trim accessories allow for a clean and finished exterior look. Available in any of our standard, designer, radiant metallic, or anodized aluminum finishes, these exterior casings add an ideal finishing touch.







AUMINUM **GIUGNOORB** 

3.112 ALLWINLEY FLAT CASING

ALUMINUM HISTORICAL BRORNOULD





7/8\* AUMINUM

BRCKWOULD

2" BULL NOSE





#### Interior Trim Options

Available in any of our rich wood interiors and finishes, these trims are expertly dried, milled and jointed together reflecting the quality you expect.









WM/376-(2-1/4-)

FLAT CASINS (3-1/21)



WM327 (2-1/4\*)

WM356(2-1/47)

WVB66 (2-1/45)

WM351 (2-1/21)



WM445 (3-1/4\*)

WNDSDR CASINS (3-1/2\*)

(SMALL AND LARCE


#### **Commercial Custom Design Solutions**

Weather Shield specializes in engineering the perfect solution for your unique window and door challenges. From the replication of historical trim to the creation of custom aluminum extrusions, Weather Shield has the expertise to ensure the success of your next commercial project:

- · Custom aluminum extrusions
- · Specialized paint and anodized finishing







# A1 Interior



# A2 Interior



## A3 Interior



A4 Interior



A5 Interior




A6 Interior




A7 Interior




A8 Interior



A9 Interior



A10 Interior





A11 Interior

B4 and B5 are wood windows with vinyl cladding outside.







## **B2** Interior





## **B4** Interior





**B5** Interior

Window C1 and C2 are casement windows Window C3- Vinyl window Window C4 - wood window with vinyl cladding outside.



# C1 & C2 Interior



C3 Interior



C4 Interior



Window D4 - wood window with vinyl cladding outside.



# D1 Interior



# D2 Interior



D3 Interior



D4 Interior K 3 0 • 25% +


| WEATHER SH<br>WINDOWS & DOO<br>P.O. Box 309 Medford, WI 5<br>weathershield.com          | ORS  | QUOTE   |           | Project D<br>Q<br>Quote D | 5/2020 05:05 PM<br>Date: 08/05/2020<br>uote #: 2389067<br>Date: 08/05/2020<br>SOneSource 1.0 |
|---|--|---|-----------|---------------------------|--|
| Sold To: 59377<br>DMC GROUP<br>13500 FOLEY ST<br>DETROIT, MI 48227                      |  | Ship To: 59377<br>DMC GROUP   |           |                           |  |
| Delivery Instructions:  |  | Deliver To:   |           |                           |  |
| LINE # QUANTITY   | ATTRIBUTES   |   |           | UNIT                      | EXTENDED   |
| $1 \qquad 1$  | Complete<br>Mfg I<br>Fram<br>See weat<br>Sizing Me<br>R/O S<br>Jamb<br>Venting F<br>Glass<br>Operating<br>Poly W<br>Exter<br>- Factory<br>Stanc<br>Stanc<br>Stanc<br>Stanc<br>Stanc<br>Stanc<br>White<br>Insulated<br>W/Ot<br>Glazing B<br>W/Ot<br>Glazing L<br>Silve<br>Silve<br>W/Int<br>1 Lite -<br>White - D | Shield Double Hung Tilt Rectangle 610 1 Wide<br>Unit<br>Date 8/8/2008 to Present<br>le Style Double Hung<br>hershield.com for PG/DP information<br>thod Jb to Jb/Frame Size - Even<br>Size 34 3/4" X 66"<br>o Size 33 3/4" X 65 1/2"<br>VO - Top 33" Venting R/O - Btm 33"<br>s Size - Top 28 5/16" X 27 7/8" - Bottom 28 5/16" X 27<br>g Code - Operating<br>/hite<br>ior Panel/Sash Color White<br>Applied<br>dard Sillnose -<br>" Installation Clips - Factory Applied<br>amb Depth -<br>finished White<br>e Vinyl Jamb Liner<br>Low E<br>ut Neat Clean Glass<br>lead Type - Colonial<br>ut Protective Film<br>bered All Sash<br>r Spacer<br>ert Airspace Gas<br>ouble Locks -<br>amb Jack Screws<br>reen - White - NO-SEE-UM Mesh - Shipped Loose<br>Unit | <b>A8</b> |                           |  |
| (Viewed from Exterior)<br>Rough Opening 34-3/4" x 66"<br>Overall Jamb 33-3/4" x 65-1/2" | Lead Time  | e: 5 Weeks  |           |                           |  |



P.O. Box 309 Medford, WI 54451 weathershield.com

### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0



(Viewed from Exterior)

Rough Opening 28-3/4" x 66" Overall Jamb 27-3/4" x 65-1/2"

WEATHER SHIELD.

#### WINDOWS & DOORS

P.O. Box 309 Medford, WI 54451 weathershield.com

### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

ATTRIBUTES LINE # QUANTITY UNIT EXTENDED 3 1 P.O.: Location: LIVING RM Job: 1035 CLARK Weather Shield Double Hung Tilt Rectangle 610 1 Wide Complete Unit 6L 13 5/0 A10 Mfg Date 8/8/2008 to Present Stationary ----- Frame Style Double Hung See weathershield.com for PG/DP information See weathers interd. Com for PG/DF information Sizing Method Jb to Jb/Frame Size - Custom Cottage Venting ----- R/O Size 44 3/4" X 66" ----- Jamb Size 43 3/4" X 65 1/2" ------ Venting Jb to Jb - Top 18 1/2" Venting Jb to Jb - Btm 47" Venting R/O -Top 18 3/4" Venting R/ 286 67 5/14 30 66 B 65 1/2 GL 42 1/8 Glass Size - Top 38 5/16" X 13 5/8" - Bottom 38 5/16" X 42 1/8" Operating Code - Top Sash Stationary Poly - - White -- Exterior Panel/Sash Color White GL 38 5/16 - Factory Applied JB 43 3/4 -- Standard Sillnose -RO 44 3/4 C3G 46 3/8 ----- 5 1/2" Installation Clips - Factory Applied 4 9/16" Jamb Depth -Pine - Prefinished White -- White Vinyl Jamb Liner Insulated Low E -- W/Out Neat Clean Glass Glazing Bead Type - Colonial ----- Tempered All Sash ----- Silver Spacer ----- W/Inert Airspace Gas 1 Lite -White - Double Locks --- No Jamb Jack Screws No Screen -Standard Unit No Field Prepping

(Viewed from Exterior) Rough Opening 44-3/4" x 66" Overall Jamb 43-3/4" x 65-1/2"


WEATHER SHIELD.

#### WINDOWS & DOORS


P.O. Box 309 Medford, WI 54451 weathershield.com

### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0



(Viewed from Exterior) Rough Opening 42-3/4" x 54" Overall Jamb 41-3/4" x 53-1/2"



(Viewed from Exterior) Rough Opening 34" x 54-1/2" Overall Jamb 33" x 54"

| WEATHER | SHIELD |
|---------|--------|
|---------|--------|

P.O. Box 309 Medford, WI 54451 weathershield.com

1

**ATTRIBUTES** 

Location: BATHROOM Job: 1035 CLARK

P.O.:


CSG 24 21/32

QUANTITY

### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

UNIT EXTENDED



| - | GL 20      | 4 |
|---|------------|---|
|   | JB 21 1/2  |   |
| - | RO 22 1/2  | - |
|   | C3G 24 1/2 | - |
| _ |            | - |

LINE #

6

Weather Shield Direct Set Rectangle 630 Direct Set 1 Wide Complete Unit -- Mfg Date 12/1/1988 to Present ----- Frame Style Double Hung See weathershield.com for PG/DP information See weathershield.com for PG/DP 1 Sizing Method Jb to Jb/Frame Size ----- R/O Size 22 1/2" X 23" ----- Glass Size 20" X 20 1/4" Primed - - Primed - Factory Applied ----- Standard Subsill ------ 5 1/2" Installation Clips - Factory Applied 4 9/16" Jamb Depth -Pine - Prefinished White Insulated Low E ----- W/Out Neat Clean Glass Glazing Bead Type - Colonial ----- W/Out Protective Film ----- Obscure ----- Tempered Glass ----- Silver Spacer ----- W/Inert Airspace Gas 1 Lite -Standard Unit No Field Prepping

# Interior window

(Viewed from Exterior)

Rough Opening 22-1/2" x 23" Overall Jamb 21-1/2" x 21-3/4"

| WEATHER | SHIELD. |
|---------|---------|
|---------|---------|

P.O. Box 309 Medford, WI 54451 weathershield.com

### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

|                         |                            |   |  |   | W    | SOneSource 1.0 |
|-------------------------|----------------------------|---|--|---|------|----------------|
| LINE # QUAN             | NTITY AT                   | TRIBUTES  |  |   | UNIT | EXTENDED       |
| LINE #     QUAN       7 | 1 P.O.:<br>Locat<br>Job: 7 | ion: KITCHEN<br>1035 CLARK<br>Weather<br>Complete<br>Fran<br>See weat<br>Sizing Me<br>R/O<br>Jaml<br>Venting F<br>Glas<br>Operating<br>Poly W<br>Exte<br>- Factory<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Who<br>Insulated<br>W/O<br>Glazing E<br>W/O<br>Silve<br>W/In<br>1 Lite -<br>White - D | Date 8/8/2008 to Present<br>te Style Double Hung<br>thershield.com for PG/DP information<br>ethod Jb to Jb/Frame Size - Even<br>Size 33 3/4" X 45 1/2"<br>to Size 32 3/4" X 45"<br>R/O - Top 22 3/4" Venting R/O - Btm 22 3/4"<br>s Size - Top 27 5/16" X 17 5/8" - Bottom 27 5/16" X 17 5/8"<br>g Code - Operating<br>White<br>rior Panel/Sash Color White<br>Applied<br>dard Sillnose -<br>"" Installation Clips - Factory Applied<br>amb Depth -<br>efinished White<br>e Vinyl Jamb Liner<br>Low E<br>ut Neat Clean Glass<br>Bead Type - Colonial<br>ut Protective Film | В | UNIT |                |
| (Viewed from Exterio    | or)                        | W/Full So<br>Standard<br>No Field   | Unit   |   |      |                |

(Viewed from Exterior) Rough Opening 33-3/4" x 45-1/2" Overall Jamb 32-3/4" x 45"

| WEATHER SH | IEL | _D。 |
|------------|-----|-----|
|------------|-----|-----|


P.O. Box 309 Medford, WI 54451 weathershield.com

### QUOTE


Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

|             |             |  |   | WSOneSource 1.0             |
|-------------|-------------|--|---|-----------------------------|
| LINE #      | QUANTIT     | Y ATTRIBUTES   | UNIT  | EXTENDED                    |
| LINE #      | QUANTIT     | P.O.:<br>Location: KITCHEN<br>Job: 1035 CLARK<br>Weather<br>Complete<br>Mfg I<br>Fram<br>See weat<br>Sizing Me<br>R/O<br>Glas<br>Operating<br>Poly W<br>Exter<br>Exter<br>Star<br>Y 9/16" J;<br>Pine - Pro | Shield Double Hung Tilt Rectangle 610 1 Wide<br>a Unit<br>Date 8/8/2008 to Present<br>the Style Double Hung<br>thershield.com for PG/DP information<br>ethod Jb to Jb/Frame Size - Even<br>Size 34" X 54 1/2"<br>o Size 33" X 54"<br>R/O - Top 27 1/4" Venting R/O - Btm 27 1/4"<br>s Size - Top 27 9/16" X 22 1/8" - Bottom 27 9/16" X 22 1/8"<br>g Code - Operating<br>/hite<br>trior Panel/Sash Color White<br>Applied<br>dard Sillnose -<br>"' Installation Clips - Factory Applied<br>amb Depth -<br>efinished White | WSOneSource 1.0<br>EXTENDED |
| (Viewed fro | m Exterior) | Insulated<br>W/O<br>Glazing E<br>W/O<br>Silve<br>W/In<br>1 Lite -<br>White - D<br>No J   | ut Neat Clean Glass<br>Sead Type - Colonial<br>ut Protective Film<br>r Spacer<br>ert Airspace Gas<br>ouble Locks -<br>amb Jack Screws<br>creen - White - NO-SEE-UM Mesh - Shipped Loose<br>Unit   |                             |

(Viewed from Exterior) Rough Opening 34" x 54-1/2" Overall Jamb 33" x 54"



Rough Opening 34-3/4" x 66" Overall Jamb 33-3/4" x 65-1/2"




(Viewed from Exterior) Rough Opening 28-3/4" x 54" Overall Jamb 27-3/4" x 53-1/2"

| WEATHER S | Shield. |
|-----------|---------|
|-----------|---------|

P.O. Box 309 Medford, WI 54451 weathershield.com

### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0



(Viewed from Exterior)

Rough Opening 28-3/4" x 62" Overall Jamb 27-3/4" x 61-1/2"

| _        | EATHER<br>WINDOWS &<br>P.O. Box 309 Medfor<br>weathershield | rd, WI 54451   | QUOTE  |
|----------|---|--|--|
| LINE #   | QUANTITY  | ATTRIBUTES   |  |
| 12       | 1   | P.O.:<br>Location: BEDROON<br>Job: 1035 CLARK  | 1  |
|          | Ψ<br>T<br>*   | Complete<br>Mfg I<br>Fram<br>See weat<br>Sizing Me<br>Sizing Me<br>Venting F<br>Glas<br>Operating<br>Poly V<br>Exter | Date 8/8/2008 to Present<br>te Style Double Hung<br>thershield.com for PG/DP information<br>ethod Jb to Jb/Frame Size - Even<br>Size 44 3/4" X 62"<br>o Size 43 3/4" X 61 1/2"<br>3/O - Top 31" Venting R/O - Btm 31"<br>s Size - Top 38 5/16" X 25 7/8" - Bottom 38 5/16" X 25 7/8"<br>g Code - Operating<br>//ite<br>rior Panel/Sash Color White |
| +=<br>+= | GL 28 5/16  | 5 1/2  | Applied<br>dard Sillnose -<br>"Installation Clips - Factory Applied  |

(Viewed from Exterior) Rough Opening 44-3/4" x 62" Overall Jamb 43-3/4" x 61-1/2"

C3G 46 3/8

Lead Time: 5 Weeks

White - Double Locks ------ No Jamb Jack Screws

W/Full Screen - White - NO-SEE-UM Mesh - Shipped Loose

4 9/16" Jamb Depth -Pine - Prefinished White ----- White Vinyl Jamb Liner

----- W/Out Neat Clean Glass Glazing Bead Type - Colonial ----- W/Out Protective Film ----- Tempered All Sash ----- Silver Spacer ----- W/Inert Airspace Gas

Insulated Low E

1 Lite -


Standard Unit No Field Prepping Printed: 08/05/2020 05:05 PM Project Date: 08/05/2020

UNIT

**A6** 

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

EXTENDED



(Viewed from Exterior)

Rough Opening 32-3/4" x 62" Overall Jamb 31-3/4" x 61-1/2"

| WEATHER SHIELD |
|----------------|
|----------------|

P.O. Box 309 Medford, WI 54451 weathershield.com


### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

| 14       1       P.O.:<br>Location: BATHROOM<br>Job: 1035 CLARK         Weather Shield Direct Set Rectangle 630 Direct Set 1 Wide<br>Complete Unit<br>Mfg Date 12/1/1988 to Present<br>Frame Style Double Hung<br>See weathershield.com for PG/DP information<br>Sizing Method Jb to Jb/Frame Size<br>R/O Size 24" X 23" |                        |  | WSOneSource 1.0 | ) |
|--|------------------------|--|-----------------|---|
| Location: BATHROOM<br>Job: 1035 CLARK<br>Weather Shield Direct Set Rectangle 630 Direct Set 1 Wide<br>Complete Unit<br>Mfg Date 12/1/1988 to Present<br>Frame Style Double Hung<br>See weathershield.com for PG/DP information<br>Sizing Method Jb to Jb/Frame Size<br>R/O Size 24" X 23"                                | LINE # QUANTITY ATTRIE | BUTES  | UNIT EXTENDED   |   |
| Glass Size 21 1/2" X 20 1/4"<br>Glass Size 21 1/2" X 20 1/4"<br>No Prime/No Fingerjoint No Prime/No Fingerjoint<br>- Factory Applied<br>   | Location:<br>Job: 1038 | <ul> <li>5 CLARK</li> <li>Weather Shield Direct Set Rectangle 630 Direct Set 1 Wide<br/>Complete Unit</li> <li> Mfg Date 12/1/1988 to Present</li> <li> Frame Style Double Hung</li> <li>See weathershield.com for PG/DP information</li> <li>Sizing Method Jb to Jb/Frame Size</li> <li> R/O Size 24" X 23"</li> <li> Jamb Size 23" X 21 3/4"</li> <li> Glass Size 21 1/2" X 20 1/4"</li> <li>No Prime/No Fingerjoint - No Prime/No Fingerjoint</li> <li>- Factory Applied</li> <li> S tandard Subsill -</li> <li> S tandard Subsill -</li> <li>Pine - Prefinished White</li> <li>Insulated Low E</li> <li> W/Out Neat Clean Glass</li> <li>Glazing Bead Type - Colonial</li> <li> W/Out Protective Film</li> <li> Obscure</li> <li> Silver Spacer</li> <li> W/Inert Airspace Gas</li> <li>1 Lite -</li> <li>Standard Unit</li> </ul> | C3              |   |

(Viewed from Exterior)

Rough Opening 24" x 23" Overall Jamb 23" x 21-3/4"



(Viewed from Exterior)

Rough Opening 28-3/4" x 62" Overall Jamb 27-3/4" x 61-1/2"

| WEATHER | SHIELD. |
|---------|---------|
|---------|---------|

P.O. Box 309 Medford, WI 54451 weathershield.com

### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

|              |             |  |   | WS   | OneSource 1.0 |
|--------------|-------------|--|---|------|---------------|
| LINE #       | QUANTITY    | ATTRIBUTES   |   | UNIT | EXTENDED      |
| LINE #<br>16 | 1<br>*<br>T | P.O.:<br>Location: ATTIC<br>Job: 1035 CLARK<br>Weather<br>Complete<br>Mfg<br>Fran<br>See weat<br>Sizing M<br>Glas<br>Operating<br>Poly V<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br>Stan<br> | Date 8/8/2008 to Present<br>the Style Double Hung<br>thershield.com for PG/DP information<br>ethod Jb to Jb/Frame Size - Even<br>Size 32 3/4" X 46"<br>b Size 31 3/4" X 45 1/2"<br>R/O - Top 23" Venting R/O - Btm 23"<br>s Size - Top 26 5/16" X 17 7/8" - Bottom 26 5/16" X 17 7/8"<br>g Code - Operating<br>Vhite<br>rior Panel/Sash Color White<br>Applied<br>dard Sillnose -<br>I'' Installation Clips - Factory Applied<br>amb Depth -<br>efinished White<br>e Vinyl Jamb Liner<br>ILow E |      |               |
|              |             | W/O<br>Glazing E<br>W/O<br>Tem<br>Silve<br>W/In<br>1 Lite -<br>White - D<br>No J   | ut Neat Clean Glass<br>Bead Type - Colonial<br>ut Protective Film<br>pered All Sash<br>er Spacer<br>ert Airspace Gas<br>Double Locks -<br>amb Jack Screws<br>creen - White - NO-SEE-UM Mesh - Shipped Loose   |      |               |

(Viewed from Exterior)

Rough Opening 32-3/4" x 46" Overall Jamb 31-3/4" x 45-1/2"

|        | EATHER<br>NINDOWS 8<br>P.O. Box 309 Medfe<br>weathershiel | ord, WI 54451  | QUOTE   | Project<br>C<br>Quote | 4/2020 01:15 PM<br>Date: 09/23/2020<br>Quote #: 2389067<br>Date: 08/05/2020<br>/SOneSource 1.0 |
|--------|---|--|---|-----------------------|--|
| LINE # | QUANTITY<br>2   | ATTRIBUTES<br>P.O.:  |   | UNIT                  | EXTENDED   |
|        | GL 17<br>18 1/2<br>19 1/2<br>19 1/2<br>19 1/2             | Comple<br>Mfg<br>Fra<br>See we<br>Sizing T<br>R/C<br>Jar<br>Gla<br>No Prini<br>- Factoo<br>Sta<br>5 1<br>4 9/16 "<br>Pine - F<br>Insulate<br>W/<br>Glazing<br>W/<br>Glazing<br>W/<br>Glazing<br>W/<br>Silang T<br>Pre<br>Pre<br>Pre<br>Pre<br>Sila | g Date 12/1/1988 to Present<br>me Style Double Hung<br>athershield.com for PG/DP information<br>Method Jb to Jb/Frame Size<br>) Size 19 1/2" X 23 1/4"<br>nb Size 18 1/2" X 22"<br>iss Size 17" X 20 1/2"<br>ne/No Fingerjoint No Prime/No Fingerjoint<br>y Applied<br>ndard Subsill -<br>/2" Installation Clips - Factory Applied<br>Jamb Depth -<br>Prefinished White<br>ed Low E<br>Dut Neat Clean Glass<br>Bead Type - Colonial<br>Dut Protective Film<br>mpered Glass<br>/er Spacer<br>nert Airspace Gas<br>ine - Wood Grille - Rectangular - Factory Applied<br>/inished White -<br>/ 2 H / | C1 & C2               |  |

(Viewed from Exterior) Rough Opening 19-1/2" x 23-1/4" Overall Jamb 18-1/2" x 22"

| WEATHER | SHIELD. |
|---------|---------|
|---------|---------|

P.O. Box 309 Medford, WI 54451 weathershield.com

#### Printed: 08/05/2020 05:05 PM Project Date: 08/05/2020

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

| UNIT | EXTENDED |
|------|----------|
|      |          |
| D1   |          |
|      | D1       |

QUOTE

(Viewed from Exterior)

Rough Opening 31-1/2" x 62" Overall Jamb 30-1/2" x 61-1/2"

| WEATHER SHIELD. | Ν | /E/ | ATH | ER | SH1 | [ELD。 |
|-----------------|---|-----|-----|----|-----|-------|
|-----------------|---|-----|-----|----|-----|-------|

P.O. Box 309 Medford, WI 54451 weathershield.com

### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

| 19 1 P.O.:<br>Location: ATTIC<br>Job: 1035 CLARK<br>Weather Shield Double Hung Tilt Rectangle 610 1 Wide<br>Complete Unit<br>  |  | WSOneSource 1.0 |   |  |               |      |
|--|--|-----------------|---|--|---------------|------|
| Location: ATTIC<br>Job: 1035 CLARK<br>Weather Shield Double Hung Tilt Rectangle 610 1 Wide<br>Complete Unit<br>  | ( ATTRIBUTES UNIT EXTEN  | UNIT EXTENDED   |   | TY ATTRIBUTES  | INE # QUANTIT | LINE |
| Pine - Prefinished White<br>White Vinyl Jamb Liner<br>Insulated Low E<br>W/Out Neat Clean Glass<br>Glazing Bead Type - Colonial<br>W/Out Protective Film<br>Tempered All Sash<br>Silver Spacer<br>W/Inert Airspace Gas<br>1 Lite - | P.O.:<br>Location: ATTIC<br>Job: 1035 CLARK<br>Weather Shield Double Hung Tilt Rectangle 610 1 Wide<br>Complete Unit<br> | UNIT EXTENDED   | te Unit<br>I Date 8/8/2008 to Present<br>me Style Double Hung<br>athershield.com for PG/DP information<br>//ethod Jb to Jb/Frame Size - Even<br>0 Size 29 3/4" X 46"<br>nb Size 28 3/4" X 45 1/2"<br>R/O - Top 23' Venting R/O - Btm 23"<br>ss Size - Top 23 5/16" X 17 7/8" - Bottom 23 5/16" X 17 7/8"<br>ng Code - Operating<br>White<br>erior Panel/Sash Color White<br>y Applied<br>ndard Sillnose -<br>/2" Installation Clips - Factory Applied<br>Jamb Depth -<br>refinished White<br>ite Vinyl Jamb Liner<br>d Low E<br>Dut Neat Clean Glass<br>Bead Type - Colonial<br>Dut Protective Film<br>npered All Sash<br>er Spacer | 1 P.O.:<br>Location: ATTIC<br>Job: 1035 CLARK<br>Weather<br>Complete<br>Mfg<br>Fran<br>See weat<br>Sizing Mt<br>Glas<br>Operating<br>Poly V<br>Stan<br>Stan<br>Whit<br>Insulated<br>Whit<br>Insulated<br>Win | 9             |      |

(Viewed from Exterior)

Rough Opening 29-3/4" x 46" Overall Jamb 28-3/4" x 45-1/2"

| W | /E | AT | HER | SHI | ELD. | Ð |
|---|----|----|-----|-----|------|---|
|---|----|----|-----|-----|------|---|

P.O. Box 309 Medford, WI 54451 weathershield.com

### QUOTE

Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

|              |               |   |  |      | SOneSource 1.0 |
|--------------|---------------|---|--|------|----------------|
| LINE #       | QUANTITY      | ATTRIBUTES  |  | UNIT | EXTENDED       |
| LINE #<br>20 | QUANTITY<br>1 | P.O.:<br>Location: STAIRCAS<br>Job: 1035 CLARK<br>Weather<br>Complete<br>Mfg I<br>Fram<br>See weat<br>Sizing Me<br>R/O<br>Jamt<br>Venting F<br>Glas<br>Operating<br>Poly W<br>Stan<br>Stan<br>5 1/2<br>4 9/16" J<br>Pine - Pro<br>Whit<br>Insulated | Shield Double Hung Tilt Rectangle 610 1 Wide<br>e Unit<br>Date 8/8/2008 to Present<br>he Style Double Hung<br>thershield.com for PG/DP information<br>ethod Jb to Jb/Frame Size - Even<br>Size 31 1/2" X 58"<br>o Size 30 1/2" X 57 1/2"<br>R/O - Top 29" Venting R/O - Btm 29"<br>s Size - Top 25 1/16" X 23 7/8" - Bottom 25 1/16" X 23 7/8"<br>g Code - Operating<br>Vhite<br>rior Panel/Sash Color White<br>Applied<br>dard Sillnose -<br>"Installation Clips - Factory Applied<br>amb Depth -<br>efinished White<br>e Vinyl Jamb Liner<br>Low E |      | EXTENDED       |
|              |               | Glazing E<br>W/O<br>Tem<br>Silve<br>W/In<br>1 Lite -<br>White - D<br>No J   | ert Airspace Gas<br>Pouble Locks -<br>amb Jack Screws<br>creen - White - NO-SEE-UM Mesh - Shipped Loose<br>Unit  |      |                |

(Viewed from Exterior)

Lead Time: 5 Weeks

Rough Opening 31-1/2" x 58" Overall Jamb 30-1/2" x 57-1/2" Miscellaneous Charges

Thank you for choosing Weather Shield Windows & Doors



P.O. Box 309 Medford, WI 54451 weathershield.com

# **Message Summary**

Printed: 08/05/2020 05:05 PM Project Date: 08/05/2020

> Quote #: 2389067 Quote Date: 08/05/2020 WSOneSource 1.0

Message # Line Item/s <u>Message</u>