

From: Jennifer Ross <rossj@detroitmi.gov>

Sent: Tuesday, March 15, 2022 1:54 PM

To: Peter Burgoyne <pburgoyne@cityclubapts.com>

Subject: RE: [EXTERNAL]RE: [EXTERNAL]Re: [EXTERNAL]RE: [EXTERNAL]RE: [EXTERNAL]RE: [EXTERNAL]RE: [EXTERNAL]RE: Detroit City Club Apartments - Grand Circus Park - Historic District Commission Question

Hi Peter,

I was able to add the mural piece to your application. However, one of the Commissioners has asked about the manner in which the murals will be installed at the parapet. Can you note the following re: the murals:

-what is the current cladding at the parapets

It is a cement board painted panel.

-how will the murals be affixed to the parapet wall? Will they be painted directly on the exterior cladding or will they be on some sort of panel which will be affixed to the wall? If so, what is the material of the panels?

We would replace or paint over the cement panels.

Once Commissioner also asked if you can provide the foot candle info or photometric info for the front façade lighting?

Attached is the data sheet, that was part of the presentation file, for the lights. They are dimmable with approx. 260-560 lumens per linear foot. The light is indirect behind a screen. The color is 2700k when white.