
Please provide a product sheet that shows the dimensions, material, color and manufacturer for the following items: the front door, the front railing, the vinyl soffits, the windows, the fencing. These can be found on websites. You can provide the digital catalogue or brochure or clip a screen shot. You can also provide a photograph of any boxes or labels of these products. If the product sheet shows various options, please indicate which option you used for your product.

FRONT DOOR -



FRONT RAILING - Adaptive Construction LLC They were custom made for the house to match the other homes in the neighborhood.

The house also already had vinyl soffits on most of the house we reused or added missing pieces to give uniform look.


Windows that were replaced were replaced by Supreme Window Factory. All of them are white.



Double Hung

- Available in replacement and new construction configurations. For ease of new construction installation, it comes with a pre-punched nailing fin.
- Fusion welded sash and frame corners assure that this window stays true and square, and fits the rough opening.
- Subtle accessory grooves come standard so you can securely accommodate trim and other attachments. Multiple accessories available.
- Dual Weatherstripping at stiles, interlock, head and sill provides extra protection against air-infiltration which enhances energy efficiency.

FENCING — I replaced the chain link fence and used the same type of fencing as the neighbors on the left side of the house.



2. Do you still have the original railing or original windows in storage? Were they all discarded?

Everything was discarded and demoed prior to my purchase of the property

3. It is stated in your report that there were no original windows when the house was purchased by the current owner. When was this house purchased? What number or percent of windows were vinyl or aluminum? Do you know how many on the front were vinyl or aluminum? Do you have any record of the condition of the original wood windows?

12/2019, 80% were vinyl windows. 20% were aluminum and wood. Bottom front were vinyl top was aluminum.

4. Vinyl windows and vinyl soffits/siding are typically not approved by the Commission as an approved material. Is the owner open to providing an alternative material to vinyl such as wood or aluminum or aluminum clad wood? Cementous siding like Hardie board or wood siding with a paint or stain is often approved. Please advise and provide the material update if you would like to update your application with a provision that may be more acceptable.

Would prefer to find a solution where everything doesn't need to be replaced.

5. The roof was replaced with new shingles without approval. This could be potentially added to the application by requesting this to be done along with providing a product sheet for the shingles were used. This is work that would otherwise be on the property as a violation for work done without approval. Please let us know that you would like to add this scope of work to the application and provide us with a product sheet for the asphalt shingles.

The roof was replaced by contractor. I am not able to reach them regarding getting a product sheet. The house also already had vinyl soffits on most of the house we reused or added missing pieces to give uniform look.

6. It appears that the front porch has new brick on the front face that does not quite match the existing brick of the house. Is this work that was done by the current owner? Would you like to add this work to the application? This appears to be another scope of work that was done without approval.

We only tuckpointed in a few areas around the house. Brick was already there.

7. There was a garage in the rear of the property that appears to have been demolished without approval. Can you tell us more about this activity? Would you like to add this work that was done without approval to this application? If so, we do need any photos of this garage (interior and exterior) and a description of its condition. An expert description (by an architect or engineer) would be most helpful if you have this.

No garage was there when purchase.