

## Audra Dye

---

**From:** Tim Flintoff <tim.flintoff@4545architecture.com>  
**Sent:** Tuesday, July 8, 2025 10:27 AM  
**To:** Audra Dye  
**Cc:** Alissa Jacobs  
**Subject:** [EXTERNAL] 1760 Wabash

Audra,

In follow up to our site meeting this morning.

The proposed siding will be 7.25" beveled profile, western red cedar siding, grade is: vertical grain clear. The installation will be overlapped of the 7.25" siding to maintain a 4-1/2" exposure, the additional overlapping of the 7.25" siding will allow for an increased overlapping profile and enhance the shadow line between laps boards. The siding will be field primed and painted. The trim will be 3-1/2" pine as detailed in the our submission and will be eastern white pine or western yellow pine, Grade: clear and field primed and painted.

--

Regards,

Timothy Flintoff, AIA, NCARB  
Principal  
c|248.320.6098  
o|313.450.4545

4545 Architecture

2761 E. Jefferson Ave. Suite 302  
Detroit, MI 48207