



# HISTORIC DISTRICT COMMISSION ADDITIONAL INFORMATION REQUEST

City of Detroit - Planning & Development Department  
2 Woodward Avenue, Suite 808  
Detroit, Michigan 48226

**Date:** 05/01/2026

**Application Number:** HDC2026-00190

## APPLICANT & PROPERTY INFORMATION

<b>NAME:</b> Craig Kallen		<b>COMPANY NAME:</b> Wet Custom Pools Design	
<b>ADDRESS:</b> 5285 7 Mile Road	<b>CITY:</b> South Lyon	<b>STATE:</b> MI	<b>ZIP:</b> 48178
<b>PROJECT ADDRESS:</b> 70 W Boston Blvd			
<b>HISTORIC DISTRICT:</b> Boston-Edison			

## REQUESTED INFORMATION

We have received your application, but it is not yet complete for review. Please provide additional details based on the comments and questions listed below. Should you need to attach additional files per this request, use the paperclip icons at the end of this form. You may attach up to (5) files per icon up to 25MB:

Thank you for the clarification. We will still need the following information before we can move forward with this application:

1. Product details on the concrete that will be used for the addition. Please note, "bright white" is not an appropriate addition. Concrete, typically, must be composed of an exposed aggregate, tinted grey, or finished with a clear or tinted grey curing compound. This also should not interfere with the public right of way.

## APPLICANT RESPONSE

Response Date: 05/01/2026



We plan on doing the exposed aggregate with a gray tint. We will not interfere with the right way.

